

【施設維持管理情報 平成26年度】

9月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 月	177	175	170	998	1,000	1,000	2.0	2.0	2.0
2 火	177	175	175	1,005	1,020	1,001	1.5	2.2	2.5
3 水	176	176	172	1,005	1,000	998	1.6	1.3	1.6
4 木	175	175	173	999	990	1,000	1.5	1.2	1.7
5 金	177	178	177	1,000	1,000	1,000	1.5	1.3	2.0
6 土	175	180	175	1,000	998	1,005	2.3	1.3	2.5
7 日									
8 月	170	175	178	1,000	1,000	1,000	1.5	2.6	2.6
9 火	175	175	178	998	1,005	990	1.2	1.3	2.0
10 水	170	175	176	994	998	1,000	2.0	2.2	1.5
11 木	175	177	175	1,000	1,000	1,010	2.2	1.5	2.5
12 金	170	175	175	1,000	1,000	990	2.0	1.5	1.5
13 土									
14 日									
15 祝									
16 火	175	175	176	990	998	999	2.0	1.2	1.3
17 水	170	175	175	1,005	1,010	998	2.5	1.5	1.6
18 木	179	172	175	1,000	1,000	1,000	1.2	1.3	2.0
19 金	178	177	175	1,000	1,015	990	1.5	2.0	2.0
20 土	170	175	176	990	1,000	998	2.0	1.2	1.3
21 日	170	175	177	998	990	998	2.2	2.1	1.5
22 月	175	178	175	1,000	1,000	1,000	1.5	1.6	1.2
23 祝	175	175	177	990	998	1,000	2.0	1.6	1.3
24 水	171	170	175	1,010	997	1,005	2.1	1.3	1.1
25 木	175	170	176	1,000	992	997	2.0	2.1	1.7
26 金	169	175	173	998	1,005	1,000	1.5	1.9	2.0
27 土	175	177	175	1,000	997	1,000	1.2	1.8	1.9
28 日	177	169	175	1,000	1,005	990	2.0	1.8	1.9
29 月	179	170	176	999	1,001	992	1.7	1.7	2.0
30 火	175	175	177	999	998	989	1.2	2.2	2.1