

【施設維持管理情報 平成26年度】

11月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 土	175	167	170	999	1,000	100	1.5	2.0	2.5
2 日	170	177	175	1,000	1,000	1,005	1.5	1.3	1.7
3 祝	170	175	176	1,001	1,000	1,001	1.2	1.5	1.3
4 火	169	169	168	1,000	1,000	992	1.1	1.2	1.2
5 水	177	179	174	1,002	991	999	1.2	1.0	1.5
6 木	175	170	173	998	1,001	1,000	1.3	1.2	1.3
7 金	176	175	176	997	1,012	1,001	2.0	1.1	1.1
8 土	177	169	175	1,000	997	1,005	1.0	1.5	1.0
9 日	175	175	179	1,001	999	999	1.2	1.6	1.0
10 月	175	173	178	1,005	1,001	1,000	2.1	1.2	1.2
11 火	174	174	171	1,000	1,002	1,000	2.1	1.3	1.4
12 水	169	175	162	999	1,003	1,000	1.5	1.2	1.5
13 木	181	177	175	997	1,000	1,001	1.2	1.5	1.6
14 金	168	177	174	1,001	1,000	998	1.3	1.6	2.0
15 土	170	175	175	990	991	1,005	1.4	1.3	1.2
16 日	172	175	177	1,000	997	1,000	1.6	1.1	1.1
17 月	175	179	176	1,010	1,000	1,001	1.2	1.0	1.0
18 火	175	169	179	1,002	1,000	999	1.3	1.2	1.0
19 水	177	165	175	1,000	1,000	1,000	1.5	1.0	1.5
20 木	170	171	176	990	997	1,010	1.3	1.2	1.2
21 金	170	175	166	1,000	999	997	1.6	1.2	2.0
22 土	162	172	170	990	1,001	1,000	1.2	1.0	1.5
23 日	175	179	171	1,010	1,000	1,000	1.3	1.3	1.6
24 祝	175	175	175	900	1,000	1,000			
25 火	175	177	169	991	1,001	1,000	1.5	1.4	1.0
26 水	170	172	176	999	997	1,001	1.2	1.5	1.3
27 木	172	171	175	1,000	1,000	1,002	1.1	1.2	1.2
28 金	174	169	170	1,000	1,000	1,000	1.3	1.6	1.5
29 土	173	175	175	1,000	1,000	1,000	1.2	1.5	1.4
30 日									