

【施設維持管理情報 平成27年】

1月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 祝									
2 金									
3 土									
4 日									
5 月	175	175	176	1,000	1,002	1,003	1.0	1.2	1.1
6 火	177	178	177	999	1,001	997	1.2	1.1	1.2
7 水	170	179	170	998	1,000	1,005	1.7	1.0	1.0
8 木	181	180	172	997	1,000	1,020	1.6	0.7	1.2
9 金	175	169	175	1,000	1,000	1,000	1.0	1.9	1.3
10 土	177	175	170	1,001	999	1,002	1.0	0.7	1.1
11 日	175	170	172	1,000	997	1,005	1.2	0.7	0.5
12 祝	171	175	175	1,002	998	1,001	1.3	0.5	1.0
13 火	169	175	178	998	1,000	1,000	1.6	1.0	1.0
14 水	175	176	170	1,000	1,000	999	2.0	1.1	1.2
15 木	176	177	189	1,000	1,001	997	1.0	1.5	1.3
16 金	170	173	170	1,001	1,002	993	1.2	1.9	1.4
17 土	179	173	175	999	1,003	1,000	1.3	1.1	1.1
18 日	175	180	174	997	1,000	991	1.5	1.0	1.0
19 月	170	175	171	1,000	1,000	1,002	1.0	0.5	1.1
20 火	181	175	179	1,001	1,000	1,000	1.6	0.6	0.7
21 水	169	175	175	991	997	1,000	1.7	1.1	0.5
22 木	175	181	177	1,002	1,000	1,002	1.0	1.0	0.9
23 金	175	179	175	1,011	1,002	1,005	0.5	1.2	1.9
24 土	176	160	175	1,000	1,003	1,007	1.3	1.0	0.9
25 日	174	175	175	1,000	1,007	1,010	1.4	1.3	1.0
26 月	175	175	175	1,001	1,020	1,000	1.7	0.7	1.2
27 火	173	170	175	1,003	1,000	1,002	1.0	0.5	1.2
28 水	170	175	175	999	1,000	1,001	1.0	1.0	1.0
29 木	181	175	175	998	1,000	1,001	1.1	1.0	1.0
30 金	176	171	177	1,000	1,002	1,000	1.0	1.1	1.0
31 土	175	177	175	1,001	1,000	1,000	1.2	1.4	0.9