

【施設維持管理情報 平成27年】

4月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 水	175	174	175	1,000	1,001	1,000	1.2	1.1	1.9
2 木	175	170	179	1,002	1,000	1,002	1.3	1.5	2.0
3 金	175	171	177	1,001	1,002	1,003	1.9	0.1	1.7
4 土	173	172	174	1,000	1,010	1,009	2.0	2.3	1.5
5 日	175	176	178	1,000	1,012	1,000	3.9	1.9	1.0
6 月	170	169	181	1,001	1,000	1,000	2.1	1.5	1.2
7 火	175	181	190	1,002	1,000	997	2.0	1.4	1.3
8 水	175	175	175	999	1,000	997	1.9	0.9	1.4
9 木									
10 金	170	172	179	1,002	992	1,000	2.2	1.9	2.3
11 土	175	179	175	1,012	993	1,002	3.1	2.2	1.7
12 日	170	175	175	1,000	999	999	2.2	2.4	1.7
13 月	172	172	175	1,005	1,000	1,001	2.1	1.5	1.2
14 火	175	173	170	1,003	1,002	1,000	1.9	1.6	1.3
15 水	176	175	172	1,002	1,002	1,005	1.7	2.0	1.3
16 木	177	177	169	997	1,000	992	1.0	2.1	1.4
17 金	171	176	162	997	1,000	1,000	1.2	1.5	1.0
18 土	170	179	175	1,000	1,000	1,000	2.0	1.3	1.1
19 日									
20 月	175	172	172	1,002	1,000	1,003	3.0	2.0	1.2
21 火	172	171	175	1,003	1,003	1,002	3.1	1.7	1.3
22 水	175	175	177	1,000	1,009	1,000	2.7	1.7	1.5
23 木	175	175	179	1,015	1,000	1,000	2.0	1.3	0.9
24 金	176	175	169	1,001	1,001	999	1.9	1.2	0.9
25 土	172	177	172	997	1,003	999	1.7	1.7	1.5
26 日	181	178	171	1,000	999	999	1.4	1.4	1.6
27 月	179	172	173	1,000	1,009	1,000	1.5	1.6	1.5
28 火	175	172	175	1,002	1,003	1,005	1.1	1.0	1.0
29 祝	175	173	177	1,003	1,002	1,000	1.0	1.5	1.5
30 木	171	175	174	1,002	1,000	1,000	1.9	1.7	1.0