

【施設維持管理情報 平成27年】

6月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 月	175	172	172	1,000	1,000	1,000	1.5	2.0	2.1
2 火	176	179	172	1,001	1,000	1,000	1.7	1.8	2.2
3 水	177	181	175	990	1,002	1,000	2.0	1.6	2.7
4 木	177	172	175	1,000	1,002	1,002	1.5	1.5	1.7
5 金	178	172	175	1,002	1,005	1,005	1.0	1.2	1.6
6 土	177	173	181	1,000	1,002	1,000	1.6	2.0	1.2
7 日	175	175	182	1,000	1,000	1,011	1.6	1.7	2.0
8 月	172	177	179	1,002	992	1,002	1.5	1.5	1.9
9 火	179	172	172	1,002	992	1,002	1.2	1.6	1.6
10 水	175	171	175	1,007	1,000	997	1.0	1.6	1.6
11 木	175	163	172	1,005	1,002	1,000	2.1	1.6	1.6
12 金	172	172	173	1,000	1,002	1,005	2.0	1.0	1.2
13 土	169	175	173	1,001	1,001	1,000	1.2	1.2	1.6
14 日	172	175	175	1,000	1,000	1,002	1.5	1.1	1.6
15 月	175	172	172	1,000	1,000	1,007	1.3	1.2	1.5
16 火	172	172	173	1,002	997	1,000	1.2	1.1	1.7
17 水	175	179	177	1,007	1,000	1,001	1.3	1.0	1.2
18 木	176	175	172	1,006	1,020	1,007	1.5	1.7	1.3
19 金	179	175	175	1,002	1,000	1,007	2.2	1.7	1.2
20 土	172	175	175	1,002	1,001	1,002	1.5	1.7	1.5
21 日	173	172	175	1,000	1,010	1,007	1.6	1.7	1.2
22 月	174	179	175	1,001	997	1,002	1.7	1.2	1.3
23 火	175	176	172	992	999	997	1.0	1.6	1.9
24 水	176	177	172	1,000	998	999	1.8	1.2	2.2
25 木	172	172	173	1,002	1,000	1,000	1.0	1.7	2.0
26 金	173	175	169	1,001	999	1,000	0.9	1.5	1.2
27 土	175	177	170	1,000	1,002	1,003	2.0	1.5	2.0
28 日	175	176	180	1,000	1,007	1,002	2.2	1.6	1.9
29 月	172	172	175	1,002	1,002	1,000	1.7	1.8	2.1
30 火	175	175	175	999	997	1,000	2.0	1.9	2.0