

【施設維持管理情報 平成27年】

9月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 火	168	177	172	1,000	1,000	1,002	2.0	1.7	2.1
2 水	170	175	170	1,001	1,000	1,000	1.9	2.0	2.1
3 木	175	181	172	1,002	1,001	1,001	2.1	1.9	1.9
4 金	166	170	168	1,000	1,002	1,003	2.3	1.9	1.8
5 土	170	175	172	1,002	1,000	1,002	1.0	1.7	1.7
6 日	175	175	175	1,007	1,001	1,000	1.2	1.2	1.3
7 月	175	176	175	1,000	1,000	1,000	1.3	1.6	1.5
8 火	172	176	172	1,002	1,000	1,002	1.5	1.6	1.6
9 水	173	172	170	1,000	1,000	1,009	1.9	1.7	1.2
10 木	177	175	181	1,001	1,001	1,009	1.7	2.7	1.0
11 金	170	175	179	1,011	1,009	1,002	2.0	1.9	1.9
12 土	168	175	180	1,002	1,000	1,004	2.1	2.3	1.0
13 日									
14 月	170	175	175	1,000	1,007	1,003	2.1	2.1	1.9
15 火	172	175	179	1,000	1,001	1,005	2.0	2.2	2.0
16 水	175	175	171	1,002	1,000	1,000	1.9	1.7	1.1
17 木	175	172	172	1,005	1,002	1,000	1.7	1.7	1.7
18 金	175	173	175	1,007	1,002	1,006	2.2	1.6	1.9
19 土	172	179	172	1,004	1,000	1,000	1.9	1.6	1.6
20 日	170	169	173	1,000	1,000	1,002	1.5	1.2	1.2
21 祝	175	172	172	1,000	1,000	1,000	2.0	1.9	1.9
22 祝	172	172	175	1,000	1,000	997	3.0	2.2	1.9
23 祝									
24 木	170	175	175	1,000	1,009	1,000	2.9	2.9	2.0
25 金	169	175	175	1,002	1,005	1,001	1.9	1.9	1.7
26 土	172	172	175	1,001	1,002	1,000	1.7	1.5	1.2
27 日	167	169	172	1,000	1,000	1,000	2.0	1.9	1.4
28 月	175	172	173	1,003	1,000	1,002	2.0	2.0	1.4
29 火	175	175	175	1,000	1,002	1,002	1.8	1.8	1.2
30 水	173	175	175	1,000	1,001	1,001	1.9	1.7	1.3