

【施設維持管理情報 平成27年】

11月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 日	175	177	175	1,000	1,000	1,001	2.0	1.3	2.1
2 月	172	176	175	1,002	1,000	1,003	2.1	1.2	2.0
3 祝	175	175	176	1,002	1,000	1,003	2.3	1.5	1.3
4 水	177	175	172	1,000	1,001	1,000	2.5	1.2	1.0
5 木	172	175	173	1,002	1,000	1,002	1.9	1.3	2.1
6 金	175	175	175	1,000	1,002	1,000	1.7	1.9	0.9
7 土	172	175	174	1,001	1,001	1,000	1.7	1.2	1.0
8 日	175	172	177	1,000	1,002	1,000	1.7	2.3	1.2
9 月	175	173	175	1,000	1,000	1,000	1.5	2.1	1.5
10 火	172	172	175	1,001	997	1,002	1.2	2.5	1.3
11 水	173	175	173	1,003	1,001	1,000	1.0	2.1	1.5
12 木	172	175	172	1,003	1,004	1,001	1.2	2.2	1.6
13 金	175	175	172	1,000	1,001	999	1.1	1.9	1.3
14 土	175	175	175	1,002	1,000	1,001	1.5	1.3	1.2
15 日	174	172	175	1,000	1,003	1,000	2.1	1.2	1.5
16 月	177	177	176	1,000	1,002	1,000	2.0	1.0	1.3
17 火	179	174	175	1,001	1,003	1,002	1.9	1.5	1.9
18 水	173	173	179	1,002	1,001	1,000	1.3	1.2	2.3
19 木	175	174	172	992	1,000	997	1.5	1.3	1.0
20 金	179	175	175	1,000	1,003	1,000	1.2	2.1	3.0
21 土	175	175	175	1,000	1,001	1,000	1.7	2.3	1.2
22 日	175	175	172	1,000	1,000	1,002	1.6	2.1	1.5
23 祝	175	175	175	1,000	1,001	1,004	1.2	2.5	1.9
24 火	175	175	175	1,005	1,007	1,000	1.5	2.3	2.9
25 水	174	176	172	1,001	1,000	1,001	2.2	1.9	2.3
26 木	175	177	173	1,000	1,000	1,000	2.3	1.3	1.0
27 金	177	178	175	1,001	1,002	1,000	2.1	1.5	1.9
28 土	178	172	173	1,003	1,003	1,000	2.5	1.3	2.3
29 日	172	175	172	1,002	1,001	1,001	2.1	1.2	1.9
30 月	172	173	175	1,000	1,005	1,000	1.2	1.0	1.0