

【施設維持管理情報 平成27年】

12月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 火	175	175	177	1,000	1,003	1,000	2.0	1.5	0.9
2 水	176	175	176	1,000	1,002	1,001	2.1	2.5	2.0
3 木	172	175	175	1,000	1,001	1,002	1.9	1.2	2.0
4 金	175	175	175	1,000	1,001	1,000	1.3	1.9	2.1
5 土	177	172	172	1,000	1,001	1,000	1.0	2.2	2.3
6 日	175	173	180	1,000	1,000	1,007	2.2	2.5	2.9
7 月	174	175	175	1,000	1,000	1,006	2.5	2.3	3.0
8 火	175	172	175	1,000	1,000	1,007	2.3	2.1	2.1
9 水	175	175	172	1,000	1,000	1,005	3.1	2.9	1.9
10 木	175	175	175	1,001	1,000	1,000	2.5	2.0	2.0
11 金	174	175	175	1,002	1,002	1,002	3.5	3.0	1.7
12 土	175	172	175	1,000	1,000	1,007	2.5	3.2	1.5
13 日	175	175	175	1,001	1,001	1,000	2.4	2.9	1.0
14 月	175	174	172	1,002	1,000	1,000	2.0	3.5	2.0
15 火	175	174	175	1,004	1,000	1,000	2.9	2.0	2.0
16 水	174	175	175	1,000	1,001	1,002	2.7	2.1	1.7
17 木	173	177	172	1,000	1,000	1,000	3.5	2.5	2.5
18 金	177	178	175	1,003	1,002	1,000	3.1	2.3	2.3
19 土	179	170	173	1,007	1,000	1,002	2.1	2.9	2.0
20 日	180	172	174	1,000	1,002	1,000	0.9	2.5	2.9
21 月	175	170	175	1,001	1,001	1,001	1.5	1.9	1.9
22 火	172	172	175	1,002	1,000	1,000	1.7	1.7	3.9
23 祝	175	175	175	1,002	1,000	1,000	1.9	1.7	3.2
24 木	175	175	175	1,001	1,001	1,000	1.5	2.0	3.0
25 金	175	172	175	1,002	1,002	1,002	2.9	1.9	2.9
26 土	175	173	175	1,000	1,000	1,000	2.5	2.3	3.0
27 日	175	175	174	1,003	1,003	1,000	1.9	2.1	2.7
28 月	175	176	173	1,005	1,005	1,000	2.3	2.5	1.9
29 火	175	177	172	1,006	1,000	1,000	1.9	2.1	2.9
30 水	175	170	172	1,000	1,000	1,000	2.0	2.0	3.0
31 木									