

【施設維持管理情報 平成28年】

2月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 月	175	174	173	1,000	1,000	1,001	1.9	1.9	1.7
2 火	175	175	175	1,001	1,000	1,000	1.0	1.9	1.5
3 水	177	176	175	1,002	1,000	1,002	1.2	2.0	2.0
4 木	173	175	175	1,003	1,005	1,001	1.3	2.0	2.2
5 金	179	169	176	1,000	1,007	1,002	2.0	2.6	1.0
6 土	181	180	172	1,000	1,000	1,000	2.1	2.4	2.5
7 日	175	179	162	1,000	1,003	1,002	1.9	2.3	2.1
8 月	177	172	175	1,000	1,002	1,000	2.2	2.2	1.5
9 火	174	175	172	1,000	1,000	1,003	2.7	2.0	1.2
10 水	173	175	175	1,000	1,011	1,004	2.1	1.9	1.4
11 祝	172	179	172	1,001	1,001	1,001	2.0	1.5	1.3
12 金	172	172	172	1,001	1,009	1,002	1.9	1.3	1.2
13 土	170	170	175	1,002	1,000	1,002	1.0	1.2	1.9
14 日									
15 月	172	175	172	1,000	1,024	1,000	1.5	2.2	2.1
16 火	173	175	173	1,000	1,003	1,003	1.6	2.0	2.3
17 水	174	181	175	1,000	1,002	1,004	1.9	2.0	2.3
18 木	172	175	172	1,002	1,000	1,006	2.2	2.2	2.3
19 金	175	177	173	1,001	1,001	1,009	1.9	2.1	2.4
20 土	175	172	175	1,002	1,002	1,000	2.0	2.1	2.5
21 日									
22 月	175	180	179	1,000	1,002	1,002	2.1	2.1	2.1
23 火	175	181	172	1,000	1,005	1,001	2.3	2.0	2.2
24 水	175	179	175	1,001	1,010	1,006	1.9	1.6	1.0
25 木	172	175	171	1,002	1,000	1,004	1.7	1.7	1.9
26 金	173	172	171	997	1,000	1,003	2.0	1.7	2.0
27 土	175	175	175	1,000	1,002	1,001	1.5	2.0	1.0
28 日	172	172	172	1,002	1,003	1,002	1.4	1.9	1.9
29 月	177	177	172	1,003	1,004	1,003	1.3	1.0	1.3