

【施設維持管理情報 平成28年】

3月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 火	172	171	169	1,000	1,002	1,005	1.2	1.5	1.5
2 水	175	175	172	1,000	1,000	1,002	1.5	2.0	1.6
3 木	174	177	173	1,000	1,000	1,002	1.2	1.9	2.0
4 金	173	175	174	1,000	1,002	1,000	1.9	2.5	1.9
5 土	175	175	172	1,000	1,001	1,000	2.0	2.1	2.2
6 日									
7 月	175	171	173	1,002	1,000	1,002	2.0	3.0	2.1
8 火	175	172	175	1,000	1,000	1,003	3.2	1.9	2.3
9 水	175	172	175	1,000	1,001	1,004	2.7	2.3	1.9
10 木	172	175	176	1,002	1,000	1,000	2.3	2.9	1.7
11 金	175	172	175	1,001	1,000	1,000	1.9	2.0	1.2
12 土	172	175	172	1,000	1,000	1,000	1.9	1.2	1.0
13 日									
14 月	177	182	175	1,001	1,005	1,002	1.3	1.3	1.0
15 火	177	179	172	1,000	1,002	1,000	1.4	1.5	1.0
16 水	172	175	175	991	1,000	1,000	1.9	1.9	1.9
17 木	175	172	172	1,002	1,000	1,000	1.5	3.0	2.9
18 金	175	180	175	1,003	1,000	1,001	1.7	2.0	1.2
19 土	175	169	175	1,004	1,000	1,000	2.0	2.1	1.3
20 日									
21 祝	177	172	172	1,000	1,000	1,003	2.1	1.5	1.5
22 火	169	175	175	1,000	1,000	1,001	3.0	1.5	1.5
23 水	172	177	175	1,000	1,005	1,000	2.9	1.2	1.2
24 木	180	172	175	1,002	1,003	1,000	2.0	1.3	1.7
25 金	175	175	175	1,001	1,001	1,000	1.9	1.9	2.0
26 土	170	172	175	1,000	1,002	1,000	1.3	1.9	2.3
27 日	175	175	175	1,001	1,003	1,000	1.5	2.1	2.0
28 月	170	177	172	1,000	1,005	1,000	1.3	2.0	2.1
29 火	175	172	175	1,000	1,003	1,000	1.2	1.3	2.0
30 水	175	172	175	1,000	1,001	1,000	1.1	1.7	1.9
31 木	176	175	172	1,000	1,002	1,006	1.0	2.1	2.0