

【施設維持管理情報 平成28年】

5月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 日	175	175	175	1,000	990	1,000	1.0	1.2	1.0
2 月	175	172	176	1,001	1,000	1,001	1.9	1.2	1.0
3 祝									
4 祝									
5 祝									
6 金	172	175	175	1,002	1,000	1,000	2.1	2.1	1.2
7 土	173	172	173	1,000	1,001	1,002	2.0	2.0	1.2
8 日	175	175	180	1,000	1,000	1,000	1.7	1.0	1.3
9 月	175	175	179	1,003	1,000	1,003	2.3	2.1	1.5
10 火	174	176	178	1,005	1,006	1,004	1.5	1.9	2.0
11 水	177	173	175	1,000	1,002	1,005	1.0	2.9	2.1
12 木	174	180	175	1,001	1,000	1,009	1.9	2.0	2.3
13 金	175	181	172	1,000	1,000	1,000	1.3	2.1	2.4
14 土	173	179	173	1,000	999	1,001	1.9	1.0	2.9
15 日	176	173	175	1,002	1,000	1,000	2.0	1.5	1.9
16 月	180	169	172	1,000	1,002	1,001	2.3	1.3	1.0
17 火	170	173	179	1,003	1,001	1,006	1.9	2.0	2.0
18 水	179	175	179	1,001	1,000	1,000	2.3	1.9	1.9
19 木	175	175	169	1,010	1,011	1,002	2.5	1.9	1.7
20 金	176	173	170	1,000	1,000	1,009	1.7	2.9	2.3
21 土	175	172	175	1,000	1,000	1,000	1.5	1.0	1.9
22 日	175	172	172	1,000	1,002	1,001	1.6	1.9	2.0
23 月	175	175	172	1,001	1,001	1,001	1.0	2.0	2.3
24 火	176	173	175	1,000	1,001	1,002	1.2	1.7	1.9
25 水	172	172	176	1,000	1,000	1,000	1.3	1.5	1.9
26 木	173	176	177	1,002	1,002	1,000	1.9	2.0	1.9
27 金	175	177	179	1,000	1,000	1,001	2.3	2.0	1.7
28 土	177	175	170	1,001	1,003	1,001	2.9	2.1	1.6
29 日	179	169	175	1,000	1,009	1,002	2.0	2.3	1.5
30 月	177	179	175	1,002	1,009	1,000	2.1	1.0	1.7
31 火	175	175	179	1,000	1,000	1,000	1.9	1.2	1.0