

【施設維持管理情報 平成28年】

7月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 金	175	175	170	1,000	999	1,001	1.0	1.3	1.2
2 土	172	175		1,000	1,001		1.2	1.4	
3 日	172	173	172	1,000	1,000	1,000	1.3	1.5	1.3
4 月	175	173	175	1,001	1,001	1,000	1.5	1.0	1.4
5 火	172	172	172	1,002	1,000	1,000	2.0	1.2	1.0
6 水	172	173	175	1,003	1,000	1,000	2.1	1.0	2.1
7 木	175	175	177	1,000	1,002	1,001	1.9	1.0	1.9
8 金	180	172	172	1,000	1,000	1,003	2.0	2.0	2.5
9 土	177	173	177	1,000	1,005	1,000	1.2	1.9	2.0
10 日	179	172		1,001	1,011		1.9	2.5	
11 月	175	175	175	1,000	1,001	1,000	2.1	2.1	1.7
12 火	172	175		1,000	1,009		1.7	1.0	
13 水	174	177		1,000	1,000		1.3	2.0	
14 木	170	178		1,000	1,000		1.4	1.3	
15 金	173	172	172	1,000	1,000	1,000	1.5	1.4	1.7
16 土	172	173	175	1,000	1,000	1,000	1.6	1.5	1.2
17 日	172	175		1,000	1,000	1,000	2.1	1.6	1.7
18 祝	171	177	172	1,001	1,002	1,000	2.2	1.3	1.5
19 火	175	171		1,000	1,000		2.0	1.2	
20 水	172	169	172	1,000	1,001	1,000	1.9	1.3	1.0
21 木	173	172	173	1,000	1,000	1,001	1.0	1.5	1.9
22 金	175	173	172	1,001	1,000	1,009	1.0	1.0	1.3
23 土	172	175	172	1,000	1,000	1,006	1.2	1.2	1.4
24 日	173	172		1,000	1,000		1.3	1.3	
25 月	178	172	175	1,001	1,000	1,000	2.0	1.2	1.2
26 火	179	173		1,001	1,000		2.1	1.3	
27 水	170	172	172	1,001	1,000	1,000	1.0	1.5	1.3
28 木	172	175	172	1,002	1,000	1,000	1.9	1.7	1.2
29 金	173	175		1,000	1,001		2.0	1.8	
30 土	173	177	175	1,000	1,001	1,000	2.0	1.8	1.3
31 日	172	179		1,000	1,002		1.2	1.0	