

【施設維持管理情報 平成28年】

12月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 木	175	172	175	1,000	1,000	1,001	1.2	1.5	1.3
2 金	175	178	172	1,000	1,000	1,001	1.3	2.0	1.5
3 土	175	177	175	1,000	1,000	1,001	1.5	2.7	1.4
4 日	175	175	175	1,001	1,000	1,000	1.9	2.5	1.3
5 月	172	172	175	1,000	1,000	1,000	2.9	2.1	1.9
6 火	177	174	175	1,000	1,000	1,000	2.0	1.7	1.9
7 水	175	179		1,000	1,001		1.9	1.7	
8 木	177	172	172	1,000	1,002	1,001	1.8	2.0	2.2
9 金	176	179	175	1,001	1,000	1,000	2.0	1.9	2.9
10 土	179	169	172	1,000	1,000	1,000	2.3	2.0	1.9
11 日	179	170	173	1,000	1,001	1,000	2.4	2.0	2.0
12 月	175	172		1,000	1,005		2.0	2.0	
13 火	172	171	174	1,000	1,000	1,001	1.3	2.0	2.0
14 水	173	175	174	1,000	1,000	1,000	2.0	2.3	2.3
15 木	174	174	174	1,000	1,000	1,000	1.2	2.0	2.5
16 金	175	177		1,000	1,001		1.0	1.7	
17 土	172	172	176	1,001	1,000	1,001	1.9	1.9	1.7
18 日	175	175	175	1,001	1,000	1,012	1.2	1.2	1.9
19 月	172	175	172	1,001	1,000	1,000	2.9	1.9	1.8
20 火	175	175	169	1,001	1,000	1,000	2.8	2.0	2.8
21 水	175	175	170	1,001	1,000	1,000	2.7	1.9	2.3
22 木	172	179	172	1,000	1,020	1,000	2.3	2.5	2.4
23 祝	175	160	173	1,002	1,001	1,000	2.4	2.5	2.3
24 土	172	172	174	1,001	1,000	1,000	1.9	1.9	2.5
25 日	175	175	175	1,000	1,000	1,000	2.0	1.9	2.0
26 月	175	175	170	1,001	1,000	1,001	2.9	2.9	2.9
27 火	175	175	175	1,000	1,000	1,000	2.8	2.7	1.9
28 水	172	175	175	1,000	1,000	1,000	1.9	2.3	1.9
29 木	173	175	175	1,001	1,000	1,000	2.0	1.0	1.7
30 金									
31 土									