

【施設維持管理情報 平成29年】

7月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 土	175	175	175	1,000	1,000	1,000	2.0	2.9	2.9
2 日	175	175	175	1,000	1,000	1,000	2.3	2.5	2.7
3 月	175	175	175	1,000	1,000	1,000	3.0	3.2	3.2
4 火	177	179	175	1,000	1,002	1,000	3.0	2.9	2.9
5 水	175	175	177	1,000	1,000	1,001	3.1	2.7	3.0
6 木			175			1,000			2.7
7 金			175			1,000			3.0
8 土	175	175	175	1,000	1,002	1,001	3.3	3.2	3.2
9 日	175	177	169	1,001	1,001	1,001	2.3	3.2	2.2
10 月	177	179	170	1,000	1,000	1,000	3.0	3.2	2.7
11 火	175	175	177	1,000	1,009	1,001	3.3	2.9	2.3
12 水	177	176	173	1,001	1,001	1,001	3.0	3.4	3.0
13 木	175	177	173	1,000	1,000	1,001	3.6	3.0	2.7
14 金	175	177		1,011	1,009		3.1	2.0	
15 土	175	177	177	1,000	1,002	1,000	3.5	3.2	3.7
16 日	175	175		1,000	1,001		3.0	3.2	
17 祝	177	177	175	1,001	1,000	1,000	2.7	2.1	3.2
18 火	175	177	176	1,000	1,000	1,000	2.4	2.3	3.0
19 水	177	171	175	1,005	1,000	1,001	3.3	4.0	3.9
20 木	175	175	175	1,001	1,001	1,001	3.0	2.7	2.9
21 金	175	175		1,000	1,001		3.0	3.2	
22 土	175	175		1,000	1,000		3.2	2.7	
23 日									
24 月	175	175		1,000	1,000		2.0	2.3	
25 火	175	175		1,000	1,000		2.0	3.2	
26 水	175	177	175	1,000	1,001	1,000	2.7	2.9	2.7
27 木	175	175	177	1,001	1,001	1,000	2.0	2.3	2.9
28 金	175	177	179	1,000	1,005	1,000	2.7	2.3	2.2
29 土	177	176	175	1,001	1,000	1,000	3.2	3.0	2.2
30 日			175			1,001			2.2
31 月			177			1,000			2.5