

【施設維持管理情報 平成29年】

9月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 金	175	175	177	1,020	1,001	1,000	2.3	2.7	2.9
2 土	175	175		1,001	1,002		2.0	3.0	
3 日	175	171	175	1,001	1,005	1,001	3.0	3.2	3.0
4 月	177	172	170	1,000	1,000	1,001	2.7	2.7	2.8
5 火	177	179	177	1,001	1,001	1,000	2.2	2.2	2.1
6 水	170	172	172	1,000	1,000	1,000	2.0	2.1	2.3
7 木	175	170	174	1,003	1,000	1,000	2.7	3.1	3.2
8 金	170	174	175	1,000	1,001	1,000	2.0	2.7	2.7
9 土	177	177	175	1,000	1,000	1,001	2.3	3.0	2.7
10 日			175			1,000			3.0
11 月			175			1,001			2.2
12 火			177			1,000			2.5
13 水			179			1,000			2.0
14 木	175	176	175	1,000	1,001	1,005	2.2	2.7	2.2
15 金	175	177	175	1,001	1,002	1,000	2.2	2.3	2.2
16 土			175			1,000			2.0
17 日									
18 祝	175	179	177	1,001	1,001	1,005	2.2	2.9	3.0
19 火	175	177	177	1,001	1,000	1,000	2.0	2.0	2.7
20 水	175	175	173	1,000	1,002	1,000	3.2	2.0	2.7
21 木	175	179		1,000	1,000		2.9	2.3	
22 金	175	175	177	1,001	1,001	1,002	2.0	2.9	1.9
23 祝	175	177	175	1,000	1,000	1,000	2.7	2.3	2.9
24 日	175	177		1,000	1,001		2.3	2.5	
25 月		175	177		1,000	1,000		2.2	2.7
26 火		175	175		1,000	1,001		2.9	2.1
27 水		177	177		1,000	1,001		2.3	2.7
28 木	175	177	177	1,000	1,001	1,005	2.0	2.7	2.2
29 金		175	175		1,001	1,002		2.3	2.4
30 土	175	177	179	1,001	1,000	1,000	2.9	2.5	2.5