

【施設維持管理情報 平成31年】

1月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 祝									
2 水									
3 木									
4 金									
5 土									
6 日			175			1,000			5.2
7 月	175	175	175	1,000	1,002	1,000	3.9	3.2	4.3
8 火	177	174	175	1,000	1,000	1,001	4.3	3.0	3.0
9 水	175	170	173	1,000	1,001	1,001	5.2	5.3	3.2
10 木	175	172	173	1,000	1,000	1,000	2.9	3.5	3.0
11 金	175	174	175	1,000	1,000	1,000	4.5	5.0	5.2
12 土	175	170	172	1,002	1,003	1,002	2.9	3.0	3.0
13 日	175	175	175	1,000	1,000	1,000	2.0	3.2	4.2
14 祝	175	175	175	1,001	1,000	1,000	2.2	3.0	2.0
15 火	175	174	175	1,000	1,000	1,000	1.9	2.0	2.0
16 水	175	170	175	1,000	1,000	1,000	2.2	2.4	4.2
17 木	170	175	175	1,000	1,000	1,002	2.0	2.0	1.9
18 金	175	175	175	1,001	1,001	1,003	2.2	1.7	1.4
19 土	175	172	175	1,000	1,001	1,000	1.7	1.9	1.9
20 日	175	175	177	1,000	1,000	1,000	1.2	2.0	1.7
21 月	175	175	174	1,000	1,000	1,000	2.0	2.2	1.7
22 火	175	174	173	1,001	1,001	1,002	2.0	1.3	1.4
23 水	175	175	173	1,000	1,002	1,002	2.2	2.7	1.7
24 木	175	175	170	1,000	1,000	1,000	1.2	1.2	1.4
25 金	175	175	175	1,000	1,000	1,000	2.2	2.1	2.4
26 土	175	175	170	1,000	1,000	1,000	2.0	2.2	1.7
27 日	175	175	170	1,000	1,000	1,000	2.0	2.1	2.3
28 月	170	172	173	1,003	1,000	1,001	2.6	2.3	2.3
29 火	175	175	177	1,001	1,000	1,002	2.1	2.0	1.7
30 水	170	175	174	1,000	1,000	1,000	2.0	1.4	1.7
31 木	175	175	175	1,000	1,000	1,000	1.7	1.5	1.7