

【施設維持管理情報 令和元年】

5月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 祝									
2 祝									
3 祝									
4 祝									
5 祝									
6 祝									
7 火									
8 水		175	175		1,000	1,000		3.0	3.2
9 木		175	175		1,000	1,000		2.2	2.0
10 金	173	175	175	1,000	1,000	1,001	2.0	2.1	1.7
11 土	175	175	175	1,000	1,000	1,000	2.1	2.0	2.0
12 日	173	170	175	1,000	1,000	1,002	2.0	2.1	2.1
13 月	175	172	175	1,000	1,001	1,000	2.9	3.2	2.3
14 火	175	170	172	1,000	1,000	1,001	2.3	2.7	2.3
15 水	175	175	175	1,001	1,000	1,000	3.2	2.0	2.3
16 木	175	170	173	1,000	1,000	1,000	2.0	1.7	1.9
17 金	175	175	175	1,000	1,000	1,000	2.2	2.3	2.2
18 土	175	175	172	1,000	1,000	1,000	2.0	2.1	2.5
19 日	175	175	177	1,000	1,000	1,000	2.1	1.7	1.5
20 月	175	175	170	1,000	1,000	1,000	2.9	2.7	2.7
21 火	175	175	175	1,000	1,000	1,000	2.0	2.1	2.3
22 水	175	175	175	1,000	1,000	1,000	2.1	2.2	2.1
23 木	175	175	175	1,000	1,000	1,000	3.0	2.9	2.9
24 金	175	175	177	1,000	1,000	1,000	2.1	2.3	2.4
25 土	175	175	177	1,000	1,001	1,001	3.2	3.0	2.3
26 日	175	175		1,001	1,001		2.2	2.4	
27 月		175	175		1,000	1,000		2.5	1.7
28 火	175	170	175	1,000	1,000	1,000	2.0	2.0	2.1
29 水	175	175	177	1,000	1,000	1,000	2.1	3.1	3.0
30 木	175	175	175	1,000	1,000	1,000	2.1	2.5	1.9
31 金	175	175	170	1,002	1,001	1,000	2.1	2.3	2.0