

【施設維持管理情報 令和元年】

12月

項目 時間 日	集塵器に流入する燃焼 ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 日	175	170	175	1,000	1,000	1,000	3.5	2.0	2.9
2 月	175	174	174	1,000	1,000	1,000	2.9	2.0	2.5
3 火	175	175	173	1,000	1,000	1,000	2.7	3.0	3.2
4 水	175	176	175	1,000	1,001	1,000	2.2	3.2	2.0
5 木	175	175		1,000	1,000		2.0	1.9	
6 金	175	175	175	1,000	1,000	1,002	2.2	2.7	1.9
7 土	175	175	172	1,000	1,000	1,000	1.5	1.7	2.0
8 日	175	175		1,000	1,000		2.2	2.5	
9 月	175	172	172	1,000	1,000	1,000	2.3	2.2	3.0
10 火	175	175	175	1,000	1,000	1,000	2.1	2.2	2.6
11 水	175	175	172	1,000	1,000	1,000	2.5	2.8	2.7
12 木	175	175	177	1,001	1,001	1,002	2.9	2.7	1.7
13 金	172	179	175	1,001	1,000	1,000	3.0	2.7	2.0
14 土		175	175		1,000	1,000		2.0	2.4
15 日	175	175	170	1,000	1,001	1,001	2.7	2.5	2.7
16 月	175	175	172	1,000	1,000	1,001	2.1	2.0	2.3
17 火	175	175	175	1,000	1,000	1,000	2.1	2.2	1.7
18 水	175	175	172	1,002	1,000	1,001	2.5	2.5	2.0
19 木	175	175	172	1,002	1,001	1,001	2.7	3.0	2.2
20 金	175	173	170	1,000	1,001	1,000	1.7	1.8	2.0
21 土	175	175	174	1,000	1,000	1,000	2.2	2.5	2.8
22 日	175	173	175	1,000	1,001	1,001	3.2	3.0	2.7
23 月	175	175	172	1,000	1,000	1,000	3.0	2.1	2.1
24 火	170	173	173	1,000	1,000	1,001	2.7	2.5	2.3
25 水	175	175	175	1,000	1,000	1,000	2.8	2.3	2.5
26 木	175	175	175	1,000	1,000	1,001	3.2	2.2	2.7
27 金	175	175	175	1,000	1,000	1,001	2.2	2.5	2.5
28 土	175	175	170	1,001	1,002	1,002	2.1	2.0	2.3
29 日	175	175	175	1,000	1,000	1,000	2.5	2.7	2.9
30 月									
31 火									