

【施設維持管理情報 令和2年】

2月

項目 時間 日	集塵器に流入する燃焼 ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 土	175	175	175	1,000	1,000	1,001	3.2	2.7	2.1
2 日	175	170		1,000	1,000		3.3	3.0	
3 月	175	173	175	1,001	1,001	1,002	2.7	3.3	2.0
4 火	175	170	173	1,000	1,000	1,000	2.4	2.3	2.9
5 水	175	172	175	1,000	1,002	1,002	2.4	2.5	2.7
6 木	175	174	175	1,001	1,001	1,002	3.2	3.3	3.7
7 金	175	175		1,000	1,000		2.7	2.4	
8 土	175	175	175	1,000	1,002	1,000	2.5	2.3	2.0
9 日	175	175		1,000	1,000		2.1	2.3	
10 月	175	175	177	1,000	1,000	1,001	3.0	2.1	2.3
11 祝	175	172	172	1,001	1,001	1,002	3.2	2.7	2.5
12 水	175	175	173	1,000	1,002	1,000	3.0	3.5	3.0
13 木	175	175	173	1,000	1,000	1,000	2.7	2.9	3.2
14 金	170	172	175	1,000	1,002	1,000	2.3	2.9	2.7
15 土	175	175	175	1,000	1,000	1,000	3.0	3.2	2.7
16 日	175	174	177	1,000	1,000	1,000	2.7	2.9	3.0
17 月	175	175	175	1,001	1,000	1,000	2.4	3.2	3.3
18 火	175	175	177	1,000	1,000	1,000	3.2	3.0	3.0
19 水	175	175	175	1,000	1,000	1,000	3.2	3.3	2.9
20 木	175	175	173	1,000	1,000	1,000	2.5	2.2	2.3
21 金	175	175	174	1,000	1,000	1,000	2.1	2.5	2.2
22 土		175	175		1,000	1,001		3.2	3.5
23 日	175	175	174	1,000	1,000	1,001	2.5	2.1	2.3
24 月	175	175	175	1,000	1,000	1,000	3.2	3.5	3.2
25 火			175			1,000			2.2
26 水	175	175	175	1,000	1,000	1,000	2.1	2.4	2.5
27 木	175	175	175	1,000	1,000	1,002	3.0	2.1	2.9
28 金	175	175	170	1,001	1,001	1,002	2.7	2.5	2.6
29 土	175	175	175	1,000	1,000	1,000	3.2	3.2	3.0