

【施設維持管理情報 令和2年】

5月

項目 時間 日	集塵器に流入する燃焼 ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 金	175	175	175	1,000	1,000	1,000	1.7	1.9	2.0
2 土	173	175	174	1,000	1,001	1,000	2.0	2.1	2.2
3 日									
4 祝									
5 祝									
6 祝									
7 木									
8 金	175	174	175	1,000	1,000	1,000	2.0	2.1	1.7
9 土	175	173	175	1,000	1,000	1,000	3.2	1.5	1.5
10 日	175	175	175	1,000	1,000	1,000	2.9	1.0	2.0
11 月	174	177	175	1,000	1,000	1,000	1.7	1.2	2.1
12 火	175	175	175	1,000	1,000	1,000	1.2	0.2	1.5
13 水	175	175	175	1,000	1,000	1,000	1.2	1.3	1.5
14 木	175	175	177	1,000	1,000	1,000	1.2	1.0	1.1
15 金	173	175	175	1,000	1,000	1,000	1.3	1.5	1.1
16 土	175	170	175	1,000	1,000	1,000	2.6	2.1	1.7
17 日	175	175	174	1,000	1,001	1,001	1.8	1.9	1.5
18 月	175	175	174	1,000	1,000	1,000	1.7	1.5	1.5
19 火	175	175	174	1,000	1,000	1,000	1.7	2.1	1.3
20 水	175	173	170	1,000	1,000	1,000	2.0	1.5	1.9
21 木	175	175	174	1,000	1,000	1,000	1.2	1.7	1.0
22 金	175	175	173	1,001	1,002	1,002	1.3	2.0	1.0
23 土	175	173	174	1,000	1,000	1,000	1.9	1.7	1.5
24 日	175	175	170	1,000	1,000	1,000	2.1	2.0	1.7
25 月	175	174	175	1,000	1,000	1,000	2.0	2.4	1.9
26 火	175	175	175	1,000	1,000	1,000	2.1	1.2	2.5
27 水	175	174	175	1,000	1,000	1,000	1.7	1.9	1.2
28 木	175	175	175	1,000	1,000	1,000	1.8	2.0	2.2
29 金	175	175	175	1,000	1,000	1,000	2.0	1.0	2.1
30 土	175	175	175	1,000	1,000	1,000	1.3	2.1	1.7
31 日			175						1.5