

【施設維持管理情報 平成26年度】

8月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 金	175	165	170	1,000	1,005	950	2.6	1.3	1.3
2 土	175	175	175	900	1,000	1,005	2.6	1.2	1.3
3 日	172	175	165	1,001	1,000	1,000	2.0	1.3	1.3
4 月	170	175	172	1,000	1,000	998	2.0	1.3	1.0
5 火	168	170	175	1,000	1,005	1,000	1.5	1.5	1.3
6 水		175	175		850	1,000		2.6	1.2
7 木	172	175	175	950	1,000	1,000	5.0	2.6	1.3
8 金	175	179	171	1,000	1,000	998	2.0	1.4	1.2
9 土	168	175	175	1,000	1,005	990	2.5	1.3	1.2
10 日									
11 月	160	165	175	1,000	1,000	890	2.0	2.0	1.5
12 火	170	175	175	900	1,000	1,000	2.5	1.5	1.5
13 水	172	175	178	1,000	1,005	980	2.0	2.0	1.5
14 木	175	175	178	1,000	1,000	850	2.5	2.5	1.3
15 金									
16 土									
17 日									
18 月	170	178	176	1,000	1,000	995	1.2	1.5	2.0
19 火	175	175	175	980	1,005	1,000	2.6	1.5	2.0
20 水	170	175	176	995	1,000	1,000	2.0	1.4	1.5
21 木	175	175	177	1,005	995	1,012	1.5	1.6	1.5
22 金	172	178	177	985	995	1,000	1.5	2.0	2.3
23 土	175	176	177	1,000	1,000	1,002	1.5	2.0	2.0
24 日									
25 月	165	170	175	1,005	998	990	1.2	1.5	1.3
26 火	175	176	175	850	999	1,000		2.0	1.5
27 水	189	166	170	1,000	1,000	995	2.5	1.6	1.2
28 木			175			1,000			1.5
29 金	175	170	175	1,000	1,000	998	2.6	1.5	1.5
30 土	175	175	170	990	1,000	1,000	2.0	1.6	1.7
31 日	175	176	175	1,000	1,000	1,005	2.0	2.0	2.0