

【施設維持管理情報 平成26年度】

10月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 水	178	175	176	999	998	1,000	2.0	2.1	1.9
2 木	175	180	177	1,001	1,000	997	1.9	1.5	1.2
3 金	175	177	173	1,010	1,005	1,000	2.1	1.6	2.0
4 土	176	181	168	996	999	1,000	1.5	1.7	1.3
5 日	170	169	175	1,000	1,001	1,002	2.0	1.5	1.7
6 月	177	189	177	1,011	998	1,000	1.7	1.5	2.0
7 火	179	170	176	1,000	1,000	999	2.2	1.8	1.6
8 水	180	175	175	998	997	997	2.1	2.0	1.2
9 木	170	175	169	1,000	999	997	1.5	1.4	1.7
10 金	175	176	177	998	1,000	1,001	1.2	1.5	1.6
11 土	169	170	175	1,005	1,000	1,001	2.0	1.9	1.8
12 日	167	169	175	1,000	999	1,000	3.1	2.0	1.5
13 祝	175	176	167	999	1,010	1,000	2.1	2.2	1.6
14 火	177	171	170	1,000	1,001	1,001	1.5	2.0	1.2
15 水	175	169	175	1,000	1,000	1,000	1.3	1.5	1.6
16 木	169	175	168	998	1,003	1,001	1.5	1.2	1.3
17 金	177	175	172	1,005	999	1,000	1.1	1.2	1.5
18 土	171	179	175	1,000	997	997	1.6	1.7	1.2
19 日	168	175	176	1,005	1,000	1,012	1.5	1.6	1.3
20 月	170	177	175	1,010	1,001	1,000	2.0	1.5	1.0
21 火	175	168	170	1,000	997	999	1.9	1.2	1.1
22 水	175	175	169	1,001	1,000	998	1.2	1.5	1.5
23 木	175	176	175	990	1,001	1,005	1.2	1.3	1.2
24 金	168	179	175	991	998	1,000	1.3	1.7	1.1
25 土	160	175	177	1,000	999	1,000	1.5	1.6	1.0
26 日	175	169	168	1,010	1,000	997	2.0	1.5	1.3
27 月	171	175	175	1,000	1,000	1,000	1.2	1.2	1.1
28 火	169	177	176	999	1,005	1,000	2.0	1.7	1.5
29 水	175	178	169	998	1,001	1,000	1.5	1.1	1.0
30 木	171	175	175	1,000	979	1,000	1.2	1.1	1.3
31 金	169	175	177	1,001	1,005	1,000	1.6	1.2	1.0