

【施設維持管理情報 平成26年度】

12月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 月	175	177	169	1,000	1,000	1,000	0.2	0.3	1.0
2 火	170	175	170	1,001	1,000	1,011	1.2	1.3	0.9
3 水	172	178	172	999	1,000	1,002	1.5	1.4	1.2
4 木	175	176	170	1,001	1,003	1,001	0.8	1.3	1.4
5 金	172	175	177	1,000	1,001	1,000	0.2	0.1	0.0
6 土	173	175	176	1,002	998	1,000	0.3	1.0	0.0
7 日	175	170	176	1,000	1,002	1,000	0.2	1.2	1.3
8 月	177	176	177	1,001	1,005	1,000	0.1	1.5	1.0
9 火	169	174	179	991	1,000	1,002	1.0	0.6	0.9
10 水	170	173	178	1,000	999	1,002	1.2	0.0	0.0
11 木	175	175	172	1,000	992	1,000	0.2	0.2	0.1
12 金	175	175	170	1,000	1,001	1,000	0.1	0.1	0.2
13 土	175	175	177	1,000	1,002	999	0.5	0.6	0.1
14 日	176	176	170	1,000	1,000	1,000	0.1	0.2	0.1
15 月	175	174	169	1,002	1,005	1,001	0.0	0.2	1.2
16 火	179	175	175	1,000	1,002	997	0.2	0.3	0.6
17 水	181	175	166	1,000	1,005	992	1.0	0.1	1.2
18 木	181	176	170	1,001	1,006	1,000	1.2	1.0	1.0
19 金	170	181	180	1,001	1,004	1,002	0.1	0.0	0.1
20 土	175	175	175	992	1,001	991	0.2	0.1	0.1
21 日	175	175	175	1,000	998	1,000	1.0	1.7	0.2
22 月	177	170	175	1,000	1,000	1,000	1.2	1.6	1.0
23 祝	179	175	176	991	1,002	1,002	1.5	1.7	1.2
24 水	181	169	174	992	1,003	1,003	1.0	1.5	0.6
25 木	175	182	173	999	994	999	0.9	1.2	0.3
26 金	172	179	178	1,002	999	998	0.9	1.0	1.0
27 土	169	177	181	1,001	1,012	997	1.0	1.1	1.2
28 日	170	176	175	1,000	1,000	999	1.2	1.0	1.7
29 月	175	175	177	1,000	1,000	1,000	1.2	1.0	1.1
30 火									
31 水									