

【施設維持管理情報 平成27年】

2月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 日	175	170	175	1,000	1,000	1,001	1.2	1.2	1.0
2 月	170	172	176	1,002	1,000	998	1.1	1.2	1.2
3 火	177	171	175	1,000	998	997	1.0	1.1	1.1
4 水	175	181	170	1,000	1,000	1,004	1.5	1.0	1.2
5 木	175	172	172	1,001	999	1,000	1.2	2.1	1.3
6 金	176	175	180	1,001	990	1,002	1.1	2.5	1.7
7 土	177	172	176	1,000	1,002	1,007	1.0	2.0	1.1
8 日	181	171	175	1,010	1,001	1,000	1.5	1.9	0.7
9 月	175	168	172	1,002	1,000	1,012	1.7	1.8	1.0
10 火	176	170	175	999	1,001	1,008	1.2	1.2	1.2
11 祝	174	175	175	998	1,001	1,000	1.0	1.0	1.9
12 木	170	172	175	1,000	1,003	1,000	1.5	1.2	1.2
13 金	169	175	177	999	1,001	1,001	2.5	1.1	1.8
14 土	175	175	172	1,015	1,005	999	2.1	1.0	1.1
15 日	175	181	175	1,002	1,000	998	1.5	0.2	1.7
16 月	175	172	171	1,000	1,000	1,000	2.2	1.0	0.9
17 火	175	173	170	1,001	1,000	997	1.0	1.1	1.0
18 水	176	175	175	1,002	1,001	1,001	1.2	1.2	1.1
19 木	170	175	172	1,000	999	1,007	1.5	1.5	1.2
20 金	181	175	170	1,001	998	990	1.6	1.0	0.2
21 土	175	172	175	999	1,000	1,000	1.0	1.1	1.0
22 日									
23 月	175	178	177	1,000	1,001	1,000	2.1	1.1	1.7
24 火	172	177	178	1,000	1,002	1,001	1.7	1.1	1.5
25 水	177	175	175	1,000	1,005	1,002	0.9	1.2	2.1
26 木	178	182	175	1,000	1,005	1,000	1.2	1.8	1.8
27 金	175	170	175	1,000	1,000	1,000	1.1	1.6	1.5
28 土	175	175	175	1,000	1,000	1,000	1.1	1.1	1.0