

【施設維持管理情報 平成27年】

3月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 日	175	177	175	1,000	1,000	1,000	1.0	1.1	1.0
2 月	172	173	175	1,000	1,000	1,000	1.1	1.0	1.0
3 火	175	176	177	1,001	1,002	998	1.2	1.0	1.1
4 水	175	175	175	1,000	1,000	1,002	1.3	1.2	1.2
5 木	175	172	175	999	1,001	1,012	1.5	1.3	1.3
6 金	171	175	181	1,000	1,000	1,000	1.0	1.4	1.5
7 土	170	172	169	1,000	1,000	1,002	1.2	1.5	1.2
8 日	175	179	170	1,020	1,002	1,001	1.2	1.6	1.1
9 月									
10 火	175	172	171	1,000	1,000	990	1.0	1.0	1.0
11 水	172	175	175	1,000	1,001	991	1.2	1.9	1.9
12 木	177	175	177	1,002	1,000	1,002	1.1	1.0	1.0
13 金	171	179	172	1,000	1,000	1,000	1.0	1.9	1.0
14 土	182	174	170	1,002	1,005	1,002	1.7	1.1	1.2
15 日	169	173	175	1,003	1,000	1,001	1.5	1.2	1.3
16 月	170	175	175	1,000	1,001	999	1.2	1.5	1.5
17 火	172	175	175	1,000	1,000	1,000	1.0	1.0	1.2
18 水	175	172	175	1,002	1,001	991	1.9	1.2	1.1
19 木	175	174	172	1,001	1,004	1,006	1.9	1.1	1.0
20 金	175	175	171	1,000	1,000	1,000	1.0	1.0	1.2
21 祝	172	172	177	1,000	1,002	1,003	1.0	1.7	1.0
22 日	173	171	198	1,002	1,001	998	1.2	1.0	1.2
23 月	173	169	179	1,008	1,010	1,009	1.2	1.2	1.2
24 火	175	182	175	1,000	1,000	1,000	1.2	2.0	1.5
25 水	172	175	172	1,002	1,003	1,007	1.0	1.3	1.2
26 木	170	179	175	1,000	1,001	1,000	1.0	1.2	1.3
27 金	175	171	174	1,000	1,000	1,000	1.1	1.0	1.4
28 土	175	172	173	1,002	1,000	1,002	1.7	1.7	1.0
29 日	175	173	179	1,001	1,005	1,002	1.3	1.6	1.0
30 月	175	174	175	999	1,001	1,000	1.2	1.2	1.0
31 火	174	176	175	1,002	999	1,000	1.0	1.0	0.9