

【施設維持管理情報 平成27年】

7月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 水	175	179	172	1,000	990	1,001	1.2	2.0	1.2
2 木	175	172	173	1,001	991	1,002	2.0	2.1	1.0
3 金	177	169	175	999	992	1,000	2.1	2.3	1.7
4 土	172	170	177	1,000	1,000	1,001	1.9	1.0	1.2
5 日	173	172	172	1,000	1,001	1,012	1.7	1.2	1.5
6 月	175	175	173	1,006	992	1,001	2.0	1.3	1.8
7 火	172	172	179	1,010	1,001	1,000	2.1	1.5	1.2
8 水	173	175	180	1,000	1,000	1,000	1.6	1.2	2.1
9 木	175	173	175	1,000	1,000	1,002	1.7	1.7	2.3
10 金	179	174	177	1,001	1,000	1,003	1.3	1.3	1.9
11 土	177	175	169	1,000	1,001	1,000	2.5	2.0	1.2
12 日	175	177	175	998	1,000	1,000	2.1	2.1	1.0
13 月	179	180	172	1,000	1,001	1,000	2.3	1.9	2.1
14 火	172	179	173	1,002	1,002	1,002	2.4	2.0	2.0
15 水	171	175	172	1,000	991	1,003	2.5	1.5	1.9
16 木	175	172	174	1,003	1,000	1,002	2.1	1.9	1.7
17 金	175	173	175	1,000	991	1,001	2.0	2.3	2.0
18 土	177	172	172	1,008	1,001	1,012	2.3	2.4	1.8
19 日	174	175	175	1,000	1,002	1,000	1.9	1.9	1.2
20 祝	179	173	175	1,021	1,011	1,001	1.7	1.2	2.7
21 火	179	175	175	1,000	1,001	1,003	2.0	1.0	2.7
22 水	175	179	175	1,000	1,002	1,013	2.5	2.1	2.1
23 木	178	169	172	1,002	1,000	1,001	2.1	2.0	1.2
24 金	172	170	173	1,000	1,000	1,007	2.2	2.0	1.3
25 土	173	172	175	1,002	1,000	1,007	2.2	2.1	1.2
26 日	176	170	179	1,000	1,000	1,000	2.1	2.1	1.2
27 月	175	175	177	1,000	1,005	1,000	2.0	2.0	1.3
28 火	172	177	179	1,000	1,001	1,002	1.9	1.7	1.5
29 水	175	172	178	1,000	1,002	1,000	2.3	1.9	1.7
30 木	172	175	175	1,001	1,000	1,000	2.1	1.9	1.9
31 金	174	180	173	1,000	1,000	1,001	2.0	1.9	2.0