

【施設維持管理情報 平成27年】

8月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 土	175	172	175	1,000	1,001	1,005	1.5	1.7	1.9
2 日									
3 月	173	175	172	1,001	1,001	1,002	1.0	1.9	2.1
4 火	172	175	175	1,000	1,000	1,005	2.1	1.3	2.0
5 水	175	175	177	1,002	1,002	1,000	1.9	1.2	2.3
6 木	175	177	179	1,003	1,005	1,002	1.0	1.7	1.9
7 金	177	190	178	1,001	1,012	1,003	1.2	1.0	1.2
8 土	172	170	177	992	1,009	1,001	1.3	1.5	2.0
9 日	172	172	175	1,000	1,000	999	1.9	1.2	1.7
10 月	173	173	175	1,005	1,000	1,000	2.1	1.3	2.2
11 火	175	179	177	1,000	1,000	1,002	2.3	1.7	2.1
12 水	175	175	175	1,000	1,000	1,003	1.9	1.0	2.1
13 木	172	172	172	1,001	1,002	1,000	2.0	2.1	2.0
14 金	173	175		1,002	1,000		2.1	2.0	
15 土									
16 日									
17 月									
18 火	175	172		1,000	1,002		2.1	1.2	
19 水	175	172		1,000	1,003		2.2	1.3	
20 木	175	175	173	1,001	1,003	1,002	2.1	1.5	1.7
21 金	175	177	175	1,002	1,000	1,003	1.9	1.2	1.8
22 土	172	172		1,000	1,000		1.5	1.7	
23 日			175			1,000			2.2
24 月	175	172	175	1,000	1,000	1,001	2.0	2.1	2.1
25 火	175	179	175	1,000	1,001	1,002	2.0	2.3	2.5
26 水	179	169	177	1,003	999	1,002	1.5	1.9	2.1
27 木	181	175	179	1,001	1,000	1,012	1.7	2.5	1.9
28 金	180	175	181	1,000	1,001	1,009	2.0	3.1	1.6
29 土	178	172	173	1,002	1,000	1,008	2.1	4.3	1.7
30 日	178	173	172	1,000	1,001	1,000	2.3	1.5	2.1
31 月	175	175	175	997	1,001	1,000	2.4	2.0	2.0