

【施設維持管理情報 平成27年】

10月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 木	175	179	175	1,000	1,002	999	1.3	2.2	2.0
2 金	175	173	175	1,001	1,003	1,000	1.2	2.1	2.3
3 土	172	172	172	1,000	1,001	1,001	1.0	1.9	1.0
4 日	170	175	175	1,000	1,000	1,005	1.5	1.9	1.0
5 月	175	175	172	1,002	1,000	1,000	1.2	1.3	1.2
6 火	175	175	174	1,001	1,000	1,002	2.0	0.9	1.3
7 水	172	172	173	1,000	1,001	1,003	2.3	1.2	1.9
8 木	173	174	175	1,009	1,002	1,006	1.8	1.2	1.9
9 金	173	179	176	1,000	1,002	1,000	2.5	1.3	2.0
10 土	172	175	179	1,000	1,002	1,001	2.1	1.5	1.3
11 日	175	179	178	1,000	1,001	1,000	1.9	1.6	1.4
12 祝	175	177	172	1,000	1,000	1,000	2.0	1.7	1.5
13 火									
14 水									
15 木	173	175	172	1,000	1,000	1,002	1.3	2.0	1.9
16 金	175	172	173	1,002	1,000	1,003	1.5	1.5	1.2
17 土	172	173	175	1,001	1,000	1,000	1.7	1.3	1.3
18 日	175	172	175	1,001	1,002	1,001	1.0	1.5	1.3
19 月	175	173	175	1,002	1,003	1,000	1.6	2.2	1.3
20 火	175	172	175	1,003	1,000	1,000	1.5	2.1	1.2
21 水	172	175	175	1,000	1,000	1,001	2.0	2.0	1.5
22 木	173	172	177	1,003	1,000	1,000	2.2	1.0	2.5
23 金	175	173	172	1,000	1,000	1,002	2.3	1.5	2.1
24 土	176	172	179	1,000	1,000	1,000	2.1	1.3	1.9
25 日	172	175	182	1,000	1,000	1,000	2.1	1.7	2.0
26 月	175	172	176	1,000	1,000	1,000	1.0	2.5	1.7
27 火	177	175	175	1,000	1,000	1,003	1.2	2.1	1.8
28 水	179	177	172	1,000	1,000	1,001	1.3	2.3	1.0
29 木	180	178	173	1,000	1,001	1,002	2.5	2.1	1.0
30 金	179	175	172	1,000	1,003	1,003	2.1	2.3	1.2
31 土	175	173	175	1,000	1,001	1,000	2.1	1.9	1.1