

【施設維持管理情報 平成28年】

1月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 祝									
2 土									
3 日									
4 月									
5 火	175	177	175	1,000	1,000	1,000	2.0	1.9	2.3
6 水	176	178	175	1,000	1,000	1,003	1.0	1.5	1.3
7 木	173	177	175	1,002	1,000	1,000	2.1	2.0	1.4
8 金	174	176	175	1,000	1,000	1,000	2.2	2.1	2.0
9 土	175	175	172	1,002	1,000	1,000	1.9	2.3	1.9
10 日	175	176	173	1,001	1,000	1,002	2.0	2.2	1.7
11 祝	172	175	174	1,001	1,000	1,000	2.0	2.0	2.0
12 火	176	177	175	1,000	1,001	1,001	2.3	2.5	2.0
13 水	181	179	177	1,000	1,001	1,000	2.5	1.9	2.5
14 木	170	179	176	1,000	1,000	1,001	2.1	1.7	2.9
15 金	175	175	175	1,000	1,000	1,002	2.3	2.0	3.0
16 土	174	178	174	1,000	1,000	1,000	2.3	2.3	2.1
17 日	178	172	172	1,001	1,000	1,003	2.5	1.9	2.3
18 月	179	174	179	1,000	1,002	1,001	2.1	1.7	3.0
19 火	174	175	179	1,000	1,000	1,000	2.0	1.7	2.9
20 水	173	175	179	1,002	1,000	1,000	1.7	1.7	2.9
21 木	172	172	181	1,000	1,000	1,000	1.9	1.5	2.7
22 金	173	173	172	1,001	1,000	1,000	2.2	2.0	2.0
23 土	172	171	175	1,000	1,000	1,000	2.0	2.3	2.3
24 日	175	179	175	1,000	1,000	1,000	1.5	2.4	2.4
25 月	175	180	175	1,000	1,001	1,001	0.9	2.3	2.5
26 火	175	175	172	1,002	1,002	1,001	1.9	2.1	2.0
27 水	172	179	173	1,005	1,000	1,005	2.0	2.0	2.9
28 木	175	172	172	1,000	1,000	1,000	2.1	1.9	3.2
29 金	173	173	177	997	1,001	1,002	2.5	2.0	2.1
30 土	175	175	177	1,000	1,000	1,001	2.3	2.3	3.0
31 日	175	172	175	1,000	1,002	1,006	2.4	2.5	3.0