

【施設維持管理情報 平成28年】

4月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 金	175	174	175	1,000	1,001	1,000	1.0	1.3	1.3
2 土	176	175	177	1,000	1,002	1,002	1.9	2.1	2.3
3 日									
4 月	175	172	172	1,001	1,000	1,000	2.1	2.1	2.0
5 火	177	173	173	1,002	1,003	1,000	2.5	2.3	1.9
6 水	179	175	174	1,001	1,005	1,002	2.3	1.9	2.3
7 木	175	177	176	1,000	1,000	1,003	3.0	1.7	3.1
8 金	175	175	175	1,000	1,000	1,004	1.9	0.9	3.0
9 土	175	179	175	1,001	1,001	1,000	2.0	0.9	2.0
10 日									
11 月	172	175	172	997	1,000	1,005	1.0	1.9	1.9
12 火	173	175	172	1,000	1,000	1,000	2.0	2.0	1.7
13 水	175	172	179	1,000	1,001	1,000	1.9	2.3	1.3
14 木	180	169	178	1,003	1,003	1,000	2.3	1.7	1.7
15 金	175	172	175	1,004	1,000	1,003	2.1	2.3	2.0
16 土	179	175	171	1,002	1,003	1,003	3.0	2.3	2.3
17 日									
18 月	172	174	175	1,003	1,000	1,001	1.7	1.0	2.0
19 火	175	174	172	1,000	1,000	1,000	2.0	2.9	1.2
20 水	175	173	173	1,000	1,003	1,000	2.1	3.0	1.3
21 木	175	175	174	1,003	1,001	997	2.3	2.7	1.3
22 金	175	177	177	1,001	1,000	1,000	2.5	2.1	2.0
23 土	172	177	172	1,001	1,000	1,000	3.0	2.3	2.1
24 日									
25 月	175	177	179	1,000	1,002	1,001	2.0	1.9	1.3
26 火	175	175	172	1,001	1,001	1,000	2.1	2.0	1.2
27 水	176	173	173	1,003	1,000	1,000	2.3	1.9	1.0
28 木	177	173	175	1,000	1,001	1,000	2.5	1.0	2.3
29 祝	173	175	173	1,000	1,003	1,000	1.9	1.0	2.0
30 土	172	175	173	1,000	1,000	1,000	2.0	1.2	1.9