

【施設維持管理情報 平成28年】

8月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 月	175	170	175	1,000	1,001	1,000	1.2	2.1	1.2
2 火	172	170	175	1,001	1,001	1,000	1.2	2.3	1.3
3 水	175	172	172	1,002	1,001	1,000	1.5	1.9	1.0
4 木	175	176	173	1,000	1,000	1,001	1.2	1.9	1.9
5 金	175	173	175	1,010	1,005	1,000	1.5	2.0	1.2
6 土	172	170	175	1,000	1,001	1,000	2.0	1.7	2.1
7 日	170	169	175	1,000	1,000	1,001			
8 月	173	180	177	1,000	1,000	1,000	2.2	1.7	1.2
9 火	177	179	179	1,001	1,000	1,000	1.9	2.1	2.2
10 水	172	173	179	1,000	1,006	1,006	1.0	2.3	1.9
11 祝	173	172	178	1,002	1,000	1,007	1.5	1.9	1.9
12 金	175	173	172	1,000	1,000	1,010	1.3	1.0	1.2
13 土	177	172	175	1,001	1,001	1,000			
14 日	172	173	175	1,001	1,000	1,012			
15 月	170	172	170	1,000	1,000	1,011			
16 火	175	175	190	1,000	1,000	1,000	2.3	1.3	
17 水	175	172	179	1,001	1,000	1,002	1.9	1.4	1.2
18 木	175	177	170	1,000	1,000	1,003	1.0	1.3	1.5
19 金	177	175	170	1,000	1,001	1,000	1.2	1.2	1.5
20 土	172	175	173	1,001	1,000	1,000	1.5	1.5	1.7
21 日	173	175	174	1,002	1,010	1,002	1.6	1.9	1.6
22 月	177	175	172	1,001	1,012	1,002	1.7	2.9	1.2
23 火	177	175	172	1,001	1,000	1,000	1.0	1.9	2.1
24 水	177	176	173	1,012	1,001	1,000	2.0	1.0	
25 木	173	180	172	1,000	1,000	1,002	2.1	1.5	2.3
26 金	172	171	172	1,002	1,002	1,000	1.9	1.2	1.4
27 土	172	170	172	1,001	1,000	1,006	2.7	2.1	1.2
28 日	173	175	173	1,007	1,000	1,000	2.0	2.0	
29 月	172	172	175	1,001	1,001	1,001	2.0	1.9	
30 火	173	173	172	1,000	1,000	1,000	1.9	1.7	0.9
31 水	173	173	175	1,000	1,000	1,011	1.0	1.0	1.2