

【施設維持管理情報 平成28年】

9月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 木	175	175	175	1,000	1,000	1,000	1.2	1.9	1.2
2 金	177	170		1,001	1,000		1.3	2.0	
3 土	178	178	175	1,001	1,000	1,000	1.0	2.3	1.2
4 日	170	175		991	1,000		1.9	1.9	
5 月	172	172		1,000	1,000		1.2	1.7	
6 火	170	169	180	1,001	1,002	1,003	2.0	2.0	1.3
7 水	170	175	175	1,001	1,000	1,004	1.9	1.5	1.4
8 木	172	172	175	1,002	1,000	1,000	2.1	2.0	1.5
9 金	175	175	175	1,000	1,000	1,000	2.0	2.0	1.7
10 土									
11 日	172	172	172	1,001	1,000	1,001	1.7	1.7	1.9
12 月									
13 火	175	172	175	1,001	1,001	1,001	2.0	2.3	1.4
14 水	175	175	172	1,001	1,002	1,001	2.1	2.1	1.3
15 木	172	172	175	1,000	1,000	1,002	1.9	3.0	1.9
16 金	175	175	175	1,000	1,000	1,000	1.8	1.9	1.7
17 土	177	177	177	1,002	1,000	1,000	2.9	2.9	1.0
18 日	172	177	179	1,001	1,000	1,001	1.3	1.9	1.9
19 祝	175	175	175	1,002	1,000	1,002	1.4	1.7	1.7
20 火	175	172	175	1,003	1,001	1,000	2.7	1.0	1.7
21 水	175	172	175	1,000	1,001	1,001	2.0	1.7	1.3
22 祝	177	175		1,000	1,002		1.0	1.9	
23 金	179	175	175	1,000	1,000	1,000	2.0	1.3	1.5
24 土	172	175		1,001	1,000		2.9	1.4	
25 日									
26 月	172	175	175	1,002	1,001	1,001	2.0	1.9	1.9
27 火	172	172	179	1,000	1,001	999	1.9	1.9	1.9
28 水	175	175	172	1,000	1,001	1,000	1.0	1.7	1.7
29 木	177	172	170	1,000	1,001	1,000	2.9	1.5	1.3
30 金	179	173	172	1,000	1,000	1,000	1.3	1.4	1.5