

【施設維持管理情報 平成28年】

11月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 火	175	175	175	1,000	1,000	1,000	1.0	1.3	1.7
2 水	176	172		1,000	1,000		1.2	1.4	
3 祝	175	175	172	1,001	1,000	1,000	1.3	1.4	1.3
4 金	175	175	172	1,000	1,001	1,000	1.0	1.4	1.4
5 土	172	176	173	1,000	1,000	1,000	1.9	1.5	2.0
6 日	175	177	175	1,001	1,000	1,000	1.0	2.2	2.1
7 月	177	176	172	1,000	1,001	1,000	2.0	2.1	1.9
8 火	175	172	173	1,002	1,002	1,000	2.1	1.9	1.3
9 水	173	175	172	1,000	1,000	1,000	2.3	1.7	1.4
10 木	173	174	175	1,000	1,000	1,000	1.9	1.3	1.2
11 金	172	172	172	1,000	1,000	1,000	2.0	2.0	1.3
12 土	175	166		1,000	1,001	1,000	1.7	2.1	2.0
13 日	175	171		1,000	1,000		1.6	2.3	
14 月	176	175	172	1,000	1,000	1,000	1.5	2.4	2.1
15 火	177	170	173	1,001	1,000	1,000	1.0	2.5	2.1
16 水	175	172	175	1,000	1,000	1,000	1.9	2.1	2.3
17 木	177	173	177	1,000	1,000	1,000	1.0	1.9	2.4
18 金	179	172	177	1,001	1,000	1,001	1.9	2.7	1.9
19 土	172	175	172	999	1,001	1,000	2.9	2.7	1.8
20 日	169	172	175	1,000	1,000	1,000	2.0	1.9	1.6
21 月	172	175		1,000	1,000		1.9	1.7	
22 火	173	172		1,000	1,000		2.2	2.0	
23 祝	172	172		1,000	1,000		2.3	2.1	
24 木	172	175	175	1,000	1,001	1,000	1.7	2.3	1.5
25 金	173	175	175	1,000	1,000	1,000	1.8	2.4	1.3
26 土	174	172	175	1,000	1,000	1,000	1.2	2.1	1.9
27 日	175	173		1,001	1,001		1.7	2.0	
28 月	175	177	175	1,011	1,000	1,001	1.9	1.7	2.0
29 火	175	177	175	1,000	1,000	1,010	1.0	1.7	2.5
30 水	175	178	175	1,001	1,000	1,000	2.0	1.7	2.1