

【施設維持管理情報 平成29年】

1月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 祝									
2 月									
3 火									
4 水									
5 木	175	175	177	1,000	1,001	1,002	2.0	2.1	1.7
6 金	175	172	179	1,000	1,002	1,000	2.0	2.3	1.7
7 土	175	171	175	1,000	1,000	1,005	2.1	1.9	1.9
8 日	174	173	174	1,001	1,000	1,000	2.0	1.9	1.0
9 祝	176	175	175	1,000	1,000	1,000	1.7	1.7	1.5
10 火	175	174	171	1,000	1,001	1,000	1.2	1.9	1.7
11 水	177	175	175	1,000	1,000	1,000	2.3	2.0	1.2
12 木	179	175	177	1,001	1,000	1,000	2.4	2.3	2.3
13 金	170	175	190	1,012	1,000	1,000	2.5	1.9	2.0
14 土	172	174	170	1,000	1,002	1,000	2.7	2.5	1.7
15 日	175	180	174	1,000	1,000	1,000	2.9	2.3	2.0
16 月	175	174	174	1,000	1,001	1,002	2.3	1.7	2.1
17 火	175	175	175	1,000	1,000	1,000	3.0	1.5	1.5
18 水	175	175	175	1,000	1,000	1,003	2.0	2.0	1.9
19 木	177	175	174	1,000	1,000	1,000	2.1	2.1	2.0
20 金	173	175	177	1,000	1,000	1,000	2.3	2.3	2.3
21 土	174	174	170	1,001	1,009	1,000	2.4	2.4	2.5
22 日	174	175	175	1,005	1,000	1,000	2.4	2.1	2.0
23 月	175	177		1,000	1,000		2.1	2.5	
24 火	175	174	174	1,000	1,000	1,000	2.5	2.0	2.0
25 水	175	172	174	1,000	1,000	1,001	2.2	2.2	2.5
26 木	175	169	174	1,001	1,000	1,002	2.2	2.1	1.9
27 金	174	169	174	1,000	1,000	1,000	2.3	2.3	1.7
28 土	177	170	175	1,000	1,001	1,001	2.4	2.0	2.0
29 日	175	175	175	1,000	1,000	1,000	2.0	2.0	2.1
30 月	174	175	175	1,000	1,000	1,000	1.9	1.9	2.5
31 火	175	174	175	1,001	1,000	1,002	1.9	2.0	2.0