

【施設維持管理情報 平成29年】

2月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 水	175	175	175	1,000	1,000	1,001	2.0	1.9	1.9
2 木	175	173	174	1,000	1,000	1,000	2.1	2.0	2.3
3 金	175	175	175	1,000	1,000	1,000	2.3	2.3	2.4
4 土	174	174	174	1,001	1,000	1,000	2.0	2.0	2.3
5 日	174	173	175	1,001	1,001	1,001	2.1	1.9	1.9
6 月	175	175	175	1,000	1,002	1,000	1.7	1.5	2.3
7 火	175	175	174	1,000	1,000	1,000	1.9	2.0	2.3
8 水	175	175	173	1,000	1,000	1,001	2.9	2.1	2.4
9 木	176	174	172	1,000	1,000	1,000	2.0	2.9	2.5
10 金	174	175	172	1,000	1,001	1,000	2.3	2.7	1.9
11 祝	175	175	175	1,000	1,000	1,000	3.0	1.6	2.9
12 日	170	175	174	1,002	1,002	1,001	2.5	2.3	1.9
13 月	173	175	174	1,000	1,000	1,000	2.0	2.5	1.9
14 火	174	175	173	1,005	1,000	1,000	1.9	1.5	2.0
15 水	175	174	175	1,005	1,000	1,002	1.5	2.0	1.5
16 木	172	172	175	1,001	1,000	1,000	1.7	1.7	2.3
17 金	174	173	177	1,000	1,000	1,000	2.0	2.0	2.4
18 土	175	173	174	1,000	1,000	1,000	1.9	2.9	2.7
19 日	175	175		1,000	1,000		2.2	2.9	
20 月	174	179		1,000	1,000		2.4	2.9	
21 火	174	175		1,000	1,001		1.9	2.9	
22 水	175	167	175	1,002	1,000	1,000	2.4	2.9	2.2
23 木	176	177	175	1,003	1,000	1,001	2.3	1.3	2.3
24 金	176	173	175	1,000	1,000	1,000	2.4	2.0	2.4
25 土	174	175	174	1,001	1,002	1,000	2.3	2.3	2.3
26 日	175	174	173	1,011	1,001	1,000	2.0	2.9	2.5
27 月	173	175		1,000	1,000		1.2	2.4	
28 火	179	174	172	1,000	1,000	1,000	1.3	2.3	1.9