

【施設維持管理情報 平成29年】

4月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 土	175	174	174	1,000	1,000	1,000	2.0	2.0	2.3
2 日	177	175	175	1,000	1,000	1,001	2.3	1.7	2.1
3 月	175	175	175	1,000	1,000	1,000	2.0	1.9	1.9
4 火	177	176	174	1,001	1,001	1,001	1.3	1.9	1.7
5 水	175	175	175	1,000	1,000	1,000	1.9	1.6	1.6
6 木	175	177	176	1,002	1,001	1,000	2.0	2.0	2.1
7 金	175	176	175	1,000	1,000	1,000	1.7	1.7	1.9
8 土	175	175	175	1,000	1,000	1,000	2.2	2.0	1.0
9 日	175	175		1,000	1,000		2.0	2.1	
10 月	175	177	179	1,000	1,001	1,000	2.3	1.9	2.3
11 火	175	176	177	1,000	1,000	1,000	2.3	2.5	2.1
12 水	175	177	179	1,001	1,001	1,000	2.0	2.1	2.0
13 木	175	175	175	1,000	1,000	1,000	1.3	1.9	2.0
14 金	175	175	177	1,000	1,000	1,000	2.2	2.1	1.8
15 土	175	177	169	1,000	1,001	1,002	1.7	1.9	2.2
16 日	175	177		1,000	1,000		2.0	2.1	
17 月	175	175	175	1,000	1,000	1,001	2.1	2.1	2.0
18 火	175	177	173	1,000	1,000	1,000	2.9	2.0	1.9
19 水	175	175	177	1,000	1,000	1,002	2.0	2.1	2.3
20 木	175	175	175	1,000	1,001	1,000	1.9	1.0	2.0
21 金	177	175	176	1,000	1,000	1,000	2.0	2.1	2.3
22 土	177	177	179	1,000	1,000	1,001	1.8	2.0	2.3
23 日									
24 月	175	174	175	1,000	1,000	1,000	1.9	2.9	2.7
25 火	174	170	177	1,001	1,000	1,003	2.2	1.4	2.0
26 水	175	170	175	1,000	1,000	1,000	2.0	2.1	2.1
27 木	177	177	177	1,000	1,001	1,001	2.1	2.3	2.6
28 金	175	177	177	1,000	1,002	1,002	1.6	2.9	1.7
29 祝	177	173	175	1,000	1,000	1,010	2.0	2.0	2.0
30 日	175	174	175	1,000	1,000	1,000	2.6	2.3	2.9