

【施設維持管理情報 平成29年】

5月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 月	175	175	177	1,000	1,000	1,000	2.0	2.3	1.9
2 火	175	175	175	1,000	1,000	1,000	1.1	1.8	2.0
3 祝	175	175	176	1,000	1,000	1,000	2.0	1.9	1.9
4 祝									
5 祝									
6 土									
7 日	175	175	175	1,000	1,000	1,002	2.2	2.0	2.3
8 月	175	177	175	1,001	1,001	1,002	2.1	2.9	1.7
9 火	177	178	175	1,030	1,000	1,012	1.7	1.6	2.0
10 水	179	176	175	1,000	1,002	1,000	2.2	2.0	2.3
11 木	175	175	177	1,000	1,000	1,000	2.1	2.3	2.3
12 金			175			1,000			2.0
13 土	177	175	175	1,001	1,000	1,000	1.7	1.7	2.3
14 日	177	175	175	1,000	1,000	1,001	1.5	2.5	2.3
15 月	175	175	177	1,000	1,000	1,000	2.0	2.5	2.5
16 火	175	175	175	1,000	1,009	1,000	2.0	2.1	2.3
17 水	175	179	169	1,002	1,002	1,002	2.3	2.1	2.0
18 木	175	175	170	1,000	1,000	1,002	2.0	2.1	2.0
19 金	175	175	176	1,001	1,000	1,009	2.0	2.1	2.2
20 土	177	179	179	1,000	1,000	1,009	2.0	1.9	2.0
21 日									
22 月	175	175	175	1,000	1,000	1,000	2.5	2.5	2.6
23 火	175	175	175	1,000	1,000	1,000	1.9	1.9	2.3
24 水	177	175	177	1,002	1,000	1,000	2.9	2.7	2.0
25 木			175			1,000			2.2
26 金	175	175	176	1,000	1,000	1,000	2.5	2.0	2.2
27 土	175	175	175	1,000	1,000	1,001	2.0	2.0	2.0
28 日	175	175	175	1,000	1,000	1,000	2.1	2.3	1.7
29 月	177	170	175	1,000	1,000	1,000	1.9	2.0	2.0
30 火	175	175	177	1,000	1,000	1,000	2.0	2.0	2.1
31 水	175	175	175	1,000	1,000	1,000	2.0	2.0	2.3