

【施設維持管理情報 平成29年】

10月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 日	175	175	175	1,000	1,001	1,001	2.2	2.2	2.9
2 月	177	175	173	1,000	1,000	1,000	2.0	2.7	2.0
3 火	175	176	175	1,000	1,003	1,000	2.1	2.3	2.2
4 水	177	177	177	1,001	1,000	1,002	2.2	1.9	2.0
5 木	175	175	175	1,000	1,000	1,000	2.2	2.3	2.2
6 金	175	175	175	1,000	1,000	1,002	2.5	2.7	2.1
7 土	175	175	177	1,001	1,001	1,000	2.9	2.2	3.2
8 日	177	176	173	1,002	1,002	1,003	2.0	2.2	2.2
9 祝	175	175	175	1,000	1,000	1,000	2.9	2.9	2.3
10 火	175	177	175	1,000	1,002	1,001	1.9	2.0	1.8
11 水	175	177	175	1,001	1,001	1,000	1.3	2.0	2.0
12 木		175	175		1,000	1,001		1.8	1.8
13 金	175	175	170	1,000	1,000	1,002	2.0	2.2	3.0
14 土			175			1,001			2.0
15 日									
16 月		175	176		1,002	1,001		2.2	3.0
17 火	175	175	175	1,000	1,002	1,000	2.0	1.8	2.0
18 水			175			1,002			1.9
19 木	175	177	176	1,000	1,001	1,000	2.2	2.3	2.2
20 金	177	180	179	1,001	1,001	1,002	1.8	2.0	2.0
21 土	175	175	177	1,000	1,001	1,001	1.9	2.2	2.5
22 日									
23 月	175	175	175	1,000	1,000	1,000	2.0	2.2	2.3
24 火	175	176	175	1,000	1,000	1,001	1.8	2.1	2.0
25 水	175	177	179	1,001	1,005	1,000	2.2	3.0	2.0
26 木	175	175	176	1,000	1,000	1,009	1.7	1.9	2.2
27 金	177	169	172	1,002	1,002	1,000	1.9	2.2	2.7
28 土	175	175	173	1,000	1,000	1,002	1.2	2.2	1.3
29 日			175			1,000			1.8
30 月	176	177		1,000	1,002		2.0	2.2	
31 火	175	175		1,000	1,000		2.2	2.0	