

【施設維持管理情報 平成29年】

11月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 水	175	175		1,000	1,001		1.9	2.0	
2 木	175	177	177	1,000	1,002	1,000	1.8	2.2	2.3
3 祝		175	175		1,000	1,002		2.1	2.7
4 土									
5 日									
6 月	175	175		1,000	1,000		2.2	1.7	
7 火	179	178		1,000	1,000		2.3	2.2	
8 水	175	175		1,000	1,001		1.0	2.0	
9 木	175	177		1,002	1,000		2.1	2.3	
10 金			175			1,000			2.2
11 土									
12 日	175	175		1,001	1,000		2.0	2.1	
13 月	173	177		1,001	1,001		2.3	2.0	
14 火	175	179		1,005	1,000		1.7	1.9	1.6
15 水	177	179	173	1,001	1,000	1,001	1.7	1.2	1.2
16 木	177	173	175	1,000	1,000	1,005	1.2	1.3	1.4
17 金	175	177	175	1,002	1,001	1,001	1.7	2.0	1.2
18 土	172	175	174	1,001	1,000	1,000	1.2	1.5	1.7
19 日	175	175	175	1,000	1,000	1,000	1.0	1.7	2.7
20 月	175	175	177	1,000	1,000	1,001	1.2	1.3	1.4
21 火	175	175	170	1,005	1,000	1,000	1.0	2.0	1.2
22 水	175	177	175	1,001	1,000	1,005	2.0	1.9	1.6
23 祝	177	175	173	1,004	1,000	1,004	1.4	1.6	1.3
24 金	175	174	177	1,002	1,000	1,000	2.2	2.4	1.7
25 土	175	175	177	1,001	1,000	1,000	2.0	2.0	
26 日	175	175		1,000	1,001		1.9	1.7	2.0
27 月	175	177	177	1,000	1,000	1,002	1.3	1.9	1.2
28 火	177	170	173	1,002	1,001	1,002	1.2	1.2	2.0
29 水	175	175	175	1,001	1,000	1,000	1.3	1.5	1.7
30 木	177	174	175	1,000	1,000	1,000	1.4	1.6	2.2