

【施設維持管理情報 平成29年】

12月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 金	175	175	177	1,000	1,002	1,000	1.2	1.8	1.0
2 土	175	175	175	1,000	1,000	1,000	1.5	1.6	1.9
3 日	175	174	174	1,001	1,003	1,002	2.0	2.2	1.3
4 月	175	177	173	1,000	1,001	1,000	1.7	2.0	1.9
5 火	174	177	177	1,006	1,000	1,005	1.5	2.4	2.2
6 水	175	175	175	1,000	1,000	1,002	2.2	1.9	2.5
7 木	172	175	175	1,005	1,000	1,009	1.0	1.3	1.5
8 金	175	179	179	1,001	1,000	1,001	1.8	1.6	1.0
9 土	175	177	176	1,000	1,000	1,000	2.3	2.5	2.0
10 日	172	170	175	1,000	1,000	1,002	2.0	2.1	2.3
11 月	175	179	175	1,000	1,000	1,000	2.0	1.2	1.7
12 火	175	179	175	1,000	1,000	1,001	2.0	2.7	1.9
13 水	175	172	172	1,005	1,005	1,007	1.3	1.3	1.3
14 木	175	170	177	1,000	1,000	1,003	2.2	1.9	1.7
15 金	177	175	170	1,000	1,000	1,000	2.0	1.3	1.3
16 土	175	175	175	1,002	1,000	1,009	1.7	2.0	2.3
17 日	175	175	179	1,000	1,002	1,002	2.2	2.0	2.3
18 月	170	172	172	1,002	1,001	1,001	1.5	1.7	1.6
19 火	175	175	170	1,000	1,004	1,001	2.2	1.7	1.7
20 水	175	175	175	1,000	1,000	1,000	2.0	2.1	2.7
21 木	175	175	175	1,000	1,001	1,000	2.0	1.2	1.9
22 金	177	176	175	1,002	1,005	1,000	1.7	1.5	2.7
23 祝	177	178	179	1,000	1,000	1,001	2.3	2.0	2.2
24 日									
25 月	175	177	177	1,000	1,000	1,000	1.7	2.2	2.3
26 火	170	170	175	1,000	1,009	1,000	2.2	2.5	2.0
27 水	175	175	175	1,000	1,000	1,000	1.3	1.7	1.8
28 木	175	175	177	1,004	1,007	1,000	2.0	2.7	1.8
29 金	175	175	175	1,000	1,002	1,008	1.4	1.5	1.7
30 土									
31 日									