

【施設維持管理情報 平成30年】

1月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 祝									
2 火									
3 水									
4 木									
5 金	175	175	175	1,000	1,000	1,000	2.2	2.5	1.7
6 土	175	175	175	1,000	1,000	1,000	2.0	2.3	2.0
7 日	175	177	175	1,000	1,002	1,002	2.1	2.0	2.3
8 祝	175	173	176	1,000	1,000	1,000	2.3	1.7	2.4
9 火	177	176	178	1,002	1,001	1,001	2.3	2.4	1.9
10 水	177	175	175	1,000	1,003	1,000	2.2	2.3	2.4
11 木	175	175	175	1,000	1,000	1,000	1.7	2.2	1.7
12 金	175	175	177	1,000	1,000	1,000	2.0	2.5	1.7
13 土	177	179	179	1,000	1,001	1,001	2.1	2.1	2.3
14 日	175	177	179	1,000	1,002	1,000	1.7	2.2	2.3
15 月	175	179	178	1,000	1,001	1,000	2.0	1.9	2.5
16 火	175	177	175	1,004	1,000	1,003	1.8	1.7	1.9
17 水	175	179	179	1,001	1,001	1,002	1.9	1.7	2.0
18 木	177	169	175	1,000	1,000	1,000	2.2	2.3	2.1
19 金	175	175	175	1,000	1,000	1,002	2.3	2.0	2.0
20 土	177	177	176	1,000	1,000	1,000	2.2	1.7	2.2
21 日	175	175	176	1,005	1,000	1,001	2.5	2.2	2.0
22 月	175	175	177	1,000	1,000	1,000	2.1	1.7	1.4
23 火	175	174	176	1,000	1,000	1,002	1.6	1.9	1.9
24 水	175	175	175	1,000	1,000	1,000	2.2	2.1	1.7
25 木	175	175	175	1,000	1,000	1,000	2.3	2.4	2.1
26 金	175	175	178	1,001	1,000	1,001	1.4	1.2	1.7
27 土	174	175	175	1,000	1,000	1,000	1.2	1.3	1.9
28 日	175	175	175	1,000	1,001	1,004	1.8	1.7	1.2
29 月	175	177	175	1,000	1,000	1,006	2.0	1.9	1.9
30 火	177	174	177	1,002	1,002	1,003	2.6	2.7	1.9
31 水	175	175	175	1,000	1,000	1,000	2.1	2.3	2.4