

【施設維持管理情報 平成30年】

2月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 木	175	175	175	1,000	1,000	1,000	2.2	2.0	2.3
2 金	177	175	171	1,005	1,002	1,001	2.3	1.9	1.3
3 土	181	175	179	1,002	1,000	1,000	3.0	2.3	2.2
4 日	175	175	177	1,000	1,000	1,000	2.2	2.4	2.5
5 月	177	177		1,002	1,002		1.2	1.9	
6 火			175			1,000			2.7
7 水			175			1,002			2.3
8 木			178			1,005			2.1
9 金	175	177	179	1,002	1,003	1,004	2.2	2.1	1.7
10 土	175	175	175	1,000	1,005	1,000	2.7	2.7	3.0
11 日		175	175		1,000	1,002		2.2	2.7
12 祝		175	175		1,000	1,004		2.4	2.8
13 火		175	177		1,005	1,004		2.1	1.4
14 水	175	175	173	1,002	1,000	1,003	2.1	2.4	1.9
15 木	175	177	175	1,000	1,002	1,000	2.0	2.7	2.0
16 金		175	179		1,000	1,000		2.9	2.3
17 土	170	175	172	1,000	1,001	1,001	1.7	2.3	2.9
18 日	173	175	175	1,002	1,000	1,000	1.9	2.3	3.3
19 月	175	175	177	1,000	1,000	1,002	2.0	2.9	1.9
20 火	174	173	175	1,000	1,002	1,002	2.3	1.3	1.4
21 水	175	173	174	1,000	1,000	1,000	2.5	2.5	2.7
22 木	170	174	175	1,000	1,000	1,000	2.0	2.2	1.7
23 金	175	175	175	1,000	1,000	1,000	2.0	2.3	2.3
24 土	171	175	175	1,000	1,000	1,002	1.9	2.2	1.7
25 日		175	175		1,002	1,000		2.0	2.1
26 月		175	176		1,004	1,002		2.4	2.5
27 火	177	177	175	1,000	1,000	1,000	3.1	2.2	1.9
28 水	175	173	175	1,000	1,000	1,000	2.0	2.1	2.7