

【施設維持管理情報 平成30年】

3月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 木	175	175	174	1,000	1,001	1,001	2.2	2.4	2.5
2 金	175	175	177	1,000	1,000	1,000	2.2	2.1	2.3
3 土	177	177	179	1,002	1,000	1,003	2.1	2.4	2.9
4 日	175	175		1,000	1,000		3.0	2.2	
5 月	175	177		1,000	1,004		2.2	1.9	
6 火	177	179		1,002	1,000		2.0	2.0	
7 水	175	175	175	1,000	1,000	1,000	2.2	2.1	1.7
8 木	175	175	177	1,000	1,002	1,000	2.1	2.1	2.0
9 金	179	169	170	1,005	1,000	1,001	2.2	2.3	2.3
10 土	175	175		1,000	1,000		2.2	2.5	
11 日	175	175	175	1,002	1,004	1,000	1.7	1.9	2.2
12 月	175	179	179	1,001	1,000	1,000	1.2	2.2	2.3
13 火	175	175	175	1,000	1,000	1,000	2.0	2.2	2.9
14 水	177	179	170	1,000	1,000	1,000	2.1	2.1	2.1
15 木	175	175	172	1,000	1,001	1,002	1.9	2.0	1.3
16 金	177	175	173	1,001	1,002	1,002	2.0	2.7	2.3
17 土	175	179	177	1,000	1,002	1,003	1.7	2.1	2.1
18 日		175	175		1,000	1,002		1.7	2.3
19 月	177	175	173	1,001	1,002	1,000	2.4	2.2	2.9
20 火		175	179		1,000	1,000		2.1	3.0
21 祝		177	179		1,000	1,000		2.4	3.2
22 木		175	175		1,000	1,000		2.7	2.3
23 金	175	177	175	1,004	10,004	1,001	2.1	2.4	2.0
24 土	175	174	175	1,004	1,000	1,000	1.3	2.9	1.7
25 日	173	173		1,000	1,000		2.0	2.1	
26 月		175	175		1,002	1,000		2.4	1.7
27 火	175	175		1,006	1,003		1.7	2.0	
28 水		175	175		1,000	1,000		2.1	2.2
29 木	175	173	175	1,000	1,000	1,001	2.7	2.1	2.4
30 金	174	174	175	1,002	1,000	1,000	1.7	2.0	2.0
31 土	175	175	175	1,000	1,001		2.0	2.1	1.4