

【施設維持管理情報 平成30年】

4月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 日	175	175		1,000	1,000		2.0	2.3	
2 月	175	175	177	1,000	1,004	1,004	2.1	1.7	1.9
3 火	173	175	175	1,001	1,000	1,002	2.0	1.2	2.2
4 水		175	173		1,001	1,000		1.7	2.7
5 木	174	175	175	1,001	1,000	1,002	1.5	1.7	2.4
6 金	177	174	175	1,001	1,000	1,000	2.0	1.4	1.7
7 土			175			1,004			1.9
8 日	175	175	174	1,000	1,001	1,001	2.2	2.9	2.4
9 月			174			1,000			2.3
10 火	173	173	175	1,000	1,000	1,000	2.9	1.7	2.1
11 水	174	175	175	1,000	1,001	1,001	2.2	2.3	2.3
12 木	174	174	177	1,000	1,000	1,000	2.2	2.1	2.4
13 金	174	175	175	1,001	1,000	1,000	1.7	2.2	1.7
14 土		175	174		1,002	1,002		2.7	2.9
15 日	175	175	175	1,000	1,000	1,000	1.3	1.7	1.7
16 月	175	175	175	1,000	1,000	1,002	2.1	2.2	2.3
17 火	175	176		1,001	1,002		2.1	2.4	
18 水	175	177	175	1,000	1,000	1,001	2.1	2.2	2.4
19 木	175	177	176	1,000	1,000	1,000	1.7	1.3	2.0
20 金	177	173	175	1,000	1,003	1,000	1.2	1.5	2.0
21 土	175	175		1,000	1,000		2.4	2.7	
22 日									
23 月		175	175		1,002	1,005		2.1	2.2
24 火	175	175	177	1,000	1,001	1,000	2.1	2.1	2.9
25 水	177	179	175	1,001	1,000	1,000	2.5	1.7	2.1
26 木		175	177		1,002	1,000		2.7	2.5
27 金	175	175	175	1,000	1,000	1,000	2.1	2.3	1.7
28 土	177	174	175	1,000	1,001	1,005	2.0	1.3	1.7
29 日		175	177		1,000	1,000		1.9	2.0
30 祝			175			1,000			2.1