

【施設維持管理情報 平成30年】

5月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 火		175	175		1,000	1,000		2.5	2.7
2 水	177	175	175	1,002	1,000	1,000	2.0	2.3	2.4
3 祝									
4 祝									
5 祝									
6 日									
7 月	175	175		1,000	1,000		2.3	1.7	
8 火	175	177	174	1,000	1,000	1,004	2.0	2.7	2.2
9 水	175	175	173	1,000	1,001	1,000	1.7	1.2	1.9
10 木	175	177	175	1,000	1,002	1,000	2.0	1.7	1.6
11 金									
12 土									
13 日									
14 月	175	175	177	1,000	1,001	1,000	2.0	2.3	1.7
15 火	175	175	175	1,000	1,000	1,000	2.1	2.1	2.2
16 水	175	175	175	1,000	1,000	1,000	2.2	2.5	1.7
17 木	175	175	177	1,000	1,001	1,001	3.0	2.7	2.1
18 金	177	179	175	1,002	1,000	1,000	2.2	2.9	2.1
19 土	175	175	174	1,000	1,000	1,000	2.1	2.2	1.7
20 日	173	175	174	1,000	1,000	1,000	2.0	2.1	2.1
21 月	175	177	173	1,000	1,002	1,002	2.1	1.3	1.7
22 火	175	175	175	1,002	1,001	1,003	3.0	2.7	2.2
23 水	176	174	175	1,000	1,001	1,003	2.0	2.0	2.2
24 木	175	175	175	1,000	1,000	1,000	1.7	1.7	1.7
25 金	177	171	174	1,001	1,000	1,000	2.0	2.2	2.0
26 土	175	175	173	1,000	1,000	1,002	3.2	2.7	2.2
27 日	175	175	174	1,000	1,000	1,000	2.0	2.3	2.1
28 月	174	176	177	1,002	1,000	1,000	2.1	2.4	3.0
29 火	175	175	177	1,000	1,000	1,000	2.0	2.7	2.9
30 水	177	173	174	1,000	1,000	1,000	3.2	2.7	2.7
31 木									