

【施設維持管理情報 平成30年】

6月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 金		175	175		1,000	1,001		2.0	2.1
2 土	177	174	175	1,000	1,000	1,000	2.0	3.2	3.0
3 日	173	175	175	1,002	1,001	1,000	1.7	1.7	2.1
4 月	175	177	176	1,000	1,003	1,002	1.7	2.2	2.0
5 火	177	175	174	1,001	1,000	1,000	2.0	2.1	2.3
6 水	175	175	174	1,000	1,000	1,000	2.0	1.7	1.7
7 木	179	177	177	1,000	1,000	1,002	1.2	1.7	2.6
8 金	176	175	175	1,003	1,001	1,000	2.0	1.2	1.5
9 土	175	175	175	1,000	1,000	1,000	2.8	2.7	3.1
10 日									
11 月		175	175		1,005	1,004		2.8	2.2
12 火	175	175	175	1,000	1,000	1,000	2.1	1.9	2.7
13 水	176	173	175	1,000	1,000	1,005	2.7	3.9	3.2
14 木	175	170	177	1,000	1,000	1,000	3.0	2.7	2.7
15 金	175	175	175	1,001	1,000	1,000	2.0	2.7	2.3
16 土	175	175	173	1,004	1,002	1,001	2.7	3.6	3.2
17 日	176	177	177	1,000	1,000	1,001	3.0	3.1	2.2
18 月	175	175	173	1,002	1,000	1,002	3.2	2.7	2.3
19 火	175	175	175	1,000	1,000	1,000	2.0	2.7	2.2
20 水	173	175	174	1,000	1,004	1,000	2.7	1.7	1.9
21 木	175	175	174	1,000	1,002	1,000	3.2	3.0	3.1
22 金	177	173	175	1,000	1,000	1,000	2.7	3.3	2.3
23 土	173	174	174	1,001	1,002	1,002	2.7	1.7	1.9
24 日		174	175		1,000	1,000		1.7	2.5
25 月	175	175	177	1,003	1,000	1,000	2.2	2.3	3.2
26 火	175	173	175	1,000	1,000	1,000	3.0	2.5	3.3
27 水	173	174	174	1,000	1,002	1,000	2.0	2.3	2.9
28 木	175	175	175	1,000	1,006	1,000	2.0	1.7	3.0
29 金	175	177	174	1,001	1,001	1,002	1.8	2.2	2.4
30 土	175	175	174	1,000	1,000	1,000			