

【施設維持管理情報 平成30年】

8月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 水	175	175	173	1,000	1,001	1,000	3.2	3.9	3.2
2 木	175	174	170	1,000	1,002	1,000	3.5	2.2	2.1
3 金	175	173	179	1,000	1,000	1,002	2.7	3.0	2.5
4 土	177	175	175	1,001	1,005	1,000	2.3	2.7	1.9
5 日	178	179	175	1,000	1,000	1,002	3.0	2.5	2.3
6 月	175	175	175	1,002	1,000	1,001	3.2	3.9	2.0
7 火	174	175	175	1,000	1,000	1,000	3.3	4.0	2.0
8 水	175	175	177	1,000	1,000	1,004	3.2	3.7	3.5
9 木	175	175	175	1,000	1,000	1,000	3.0	3.2	2.7
10 金		175	175		1,000	1,000		2.7	2.5
11 祝	175	177	175	1,000	1,002	1,000	3.0	3.7	4.0
12 日									
13 月									
14 火									
15 水									
16 木	175	175	175	1,000	1,000	1,000	3.5	3.7	3.2
17 金	175	174	175	1,000	1,000	1,000	3.0	3.0	3.7
18 土	175	175	177	1,001	1,001	1,002	3.2	3.9	2.9
19 日		175	175		1,000	1,000		3.0	3.2
20 月	175	175	175	1,000	1,000	1,001	3.0	3.3	2.5
21 火	175	176	175	1,000	1,001	1,002	2.3	2.7	3.2
22 水	175	175		1,000	1,000		3.0	3.5	
23 木	175	175	175	1,000	1,001	1,000	3.2	3.2	3.0
24 金	175	177	175	1,000	1,001	1,002	3.5	3.0	3.2
25 土	175	175	175	1,000	1,001	1,000	3.9	3.7	3.2
26 日	175	178	177	1,000	1,003	1,003	3.0	2.1	2.7
27 月	177	175	174	1,001	1,000	1,000	3.2	2.5	3.0
28 火	175	175	175	1,000	1,000	1,001	3.0	3.2	3.2
29 水	175	179	175	1,000	1,000	1,002	3.2	3.3	3.4
30 木	175	175	175	1,000	1,000	1,002	3.5	3.2	3.3
31 金	175	175	177	1,000	1,000	1,001	3.2	3.0	3.3