

【施設維持管理情報 平成30年】

10月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 月	175	173	173	1,000	1,000	1,002	3.0	3.2	2.9
2 火	175	175	174	1,001	1,000	1,000	3.2	3.3	2.9
3 水	177	175	175	1,005	1,000	1,000	3.9	4.2	2.8
4 木	173	175	172	1,000	1,000	1,000	3.3	3.7	3.0
5 金	175	174	170	1,000	1,000	1,002	3.0	2.7	3.3
6 土	178	173	175	1,000	1,000	1,000	3.0	3.0	3.1
7 日	177	179	175	1,000	1,000	1,001	2.7	3.4	3.0
8 祝	175	177		1,002	1,002		2.3	2.2	
9 火	174	175		1,000	1,003		3.9	2.3	
10 水	174	174	175	1,001	1,000	1,000	3.5	4.0	3.2
11 木	175	173	175	1,000	1,000	1,000	2.9	3.0	3.5
12 金	176	174	175	1,000	1,000	1,001	2.7	3.0	3.7
13 土	173	173	175	1,000	1,001	1,005	2.5	3.2	3.3
14 日	175	174	175	1,000	1,000	1,000	3.0	2.9	3.1
15 月	175	175	175	1,003	1,004	1,001	3.2	3.5	3.2
16 火	175	175	175	1,001	1,000	1,000	2.7	3.4	3.2
17 水	175	175	174	1,001	1,000	1,003	3.0	2.7	3.5
18 木	174	175	176	1,000	1,000	1,000	3.2	2.3	3.5
19 金	173	175	177	1,000	1,000	1,000	3.3	3.0	3.6
20 土	173	173	175	1,000	1,000	1,000	3.4	3.4	2.9
21 日	174	173	173	1,000	1,000	1,000	3.5	3.3	2.3
22 月	179	175	175	1,000	1,002	1,005	5.2	3.3	2.9
23 火	179	175	174	1,000	1,000	1,000	5.2	2.7	3.0
24 水	175	175	179	1,000	1,000	1,005	3.0	3.0	3.1
25 木	173	179	179	1,000	1,000	1,000	3.2	3.1	3.5
26 金	173	177	177	1,002	1,000	1,000	4.0	3.5	3.2
27 土	174	175	175	1,000	1,000	1,001	3.6	3.5	4.0
28 日	175	175	175	1,004	1,000	1,001	3.3	3.6	3.5
29 月	175	175	175	1,000	1,000	1,002	2.7	2.3	3.0
30 火	175	175	175	1,000	1,000	1,001	3.0	3.0	3.2
31 水	175	175	175	1,000	1,000	1,000	3.0	3.2	3.0