

【施設維持管理情報 平成30年】

12月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 土	175	175	173	1,000	1,001	1,000	2.3	3.0	3.5
2 日	175	175	175	1,000	1,002	1,000	3.7	3.3	3.3
3 月	174	175	173	1,001	1,000	1,000	3.5	3.5	3.4
4 火	173	175	173	1,000	1,000	1,000	3.4	3.2	3.2
5 水	175	175	177	1,000	1,000	1,000	3.0	3.2	3.5
6 木	175	177	174	1,000	1,005	1,001	2.7	3.0	3.0
7 金	175	174	175	1,000	1,000	1,000	3.4	3.4	3.0
8 土	175	174	174	1,000	1,000	1,000	2.9	2.3	3.2
9 日	175	177	175	1,000	1,002	1,000	3.5	4.0	3.5
10 月	175	173	174	1,000	1,000	1,000	4.2	3.2	3.9
11 火	175	179	175	1,000	1,000	1,000	3.5	3.7	4.2
12 水	175	179	179	1,000	1,000	1,000	4.5	4.2	3.9
13 木	175	175	175	1,000	1,000	1,000	3.7	3.0	2.9
14 金	177	174	174	1,005	1,000	1,000	5.0	3.4	3.9
15 土	175	175	174	1,000	1,000	1,002	3.5	3.5	3.7
16 日			175			1,000			4.5
17 月	175	175	179	1,000	1,000	1,001	3.5	3.4	3.3
18 火	175	175	177	1,002	1,002	1,001	4.0	5.0	3.2
19 水	175	175	174	1,000	1,000	1,000	2.7	2.3	2.9
20 木	175	175	175	1,000	1,000	1,000	3.0	3.2	3.0
21 金	177	179	170	1,000	1,000	1,002	3.2	3.2	3.3
22 土	175	175	175	1,001	1,001	1,002	3.0	3.2	3.3
23 日	175	179	170	1,000	1,001	1,000	3.2	3.9	3.3
24 祝	177	170	175	1,000	1,002	1,000	4.0	3.7	3.0
25 火	175	175	175	1,000	1,000	1,000	3.0	2.7	3.0
26 水	175	175	175	1,000	1,000	1,000	2.7	2.3	2.9
27 木	175	175	175	1,000	1,000	1,000	3.0	3.2	3.3
28 金	175	175	175	1,000	1,000	1,001	2.9	3.3	3.3
29 土	175	179	175	1,000	1,000	1,000	3.2	3.5	3.4
30 日									
31 月									