

【施設維持管理情報 平成31年】

2月

項目 時間 日	集塵器に流入する 燃焼ガスの温度(°C)			燃焼中の燃焼ガス温度 (二次焼却炉内、°C)			排ガス中の 一酸化炭素濃度(PPM)		
	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00	10:00 ~13:00	13:00 ~16:00	16:00 ~19:00
1 金	175	177	175	1,000	1,001	1,000	1.7	2.2	1.3
2 土	175	175	175	1,000	1,001	1,001	2.0	2.0	1.5
3 日	175	175	174	1,000	1,000	1,000	2.0	1.7	1.7
4 月	175	174	174	1,000	1,000	1,000	1.7	1.5	1.2
5 火	174	170	175	1,000	1,000	1,000	1.2	1.4	1.9
6 水	175	175	175	1,000	1,000	1,002	1.2	2.4	2.0
7 木	170	172	175	1,001	1,001	1,002	2.0	2.1	2.3
8 金	175	173	175	1,001	1,000	1,000	1.2	1.4	1.6
9 土	175	175	175	1,000	1,000	1,000	2.1	2.0	1.7
10 日		175	175		1,000	1,000		1.5	1.6
11 祝		175	175		1,000	1,000		2.0	4.0
12 火	175	175	175	1,000	1,000	1,000	1.7	2.0	2.2
13 水	175	170	174	1,000	1,000	1,000	1.9	1.7	1.9
14 木	175	174	175	1,000	1,000	1,000	2.0	2.2	1.7
15 金	175	177	177	1,000	1,000	1,000	1.5	1.4	1.7
16 土	175	175	170	1,000	1,000	1,000	1.2	1.3	1.5
17 日	175	173	175	1,000	1,000	1,002	2.0	1.2	1.7
18 月	175	175	177	1,001	1,000	1,000	2.2	2.0	1.9
19 火	175	175	175	1,000	1,000	1,000	2.0	2.1	2.0
20 水	175	175	175	1,000	1,000	1,001	1.7	1.2	1.3
21 木	175	175	175	1,000	1,000	1,000	1.8	1.9	2.2
22 金	170	173	175	1,000	1,000	1,000	1.2	1.7	1.4
23 土	175	172	174	1,002	1,002	1,001	1.7	1.6	1.9
24 日	175	175	174	1,000	1,002	1,000	2.2	2.0	1.7
25 月	175	175	175	1,000	1,000	1,000	2.0	2.5	1.9
26 火	175	175	174	1,000	1,000	1,000	2.2	2.4	1.2
27 水	175	175	175	1,000	1,000	1,000	1.7	1.9	1.9
28 木	175	176	177	1,001	1,000	1,002	2.0	2.4	2.9